

Shared Services Canada 180 Kent Street, 13th Floor Ottawa, Ontario K1P 0B6

JANUARY 14, 2021

ADDENDUM #1

Re: Request for Proposals BPM011620

Uninterruptible Power Supply (UPS) and Power Distribution Unit (PDU)

Shared Services Canada – National Capital Region

No consideration will be given for extras and/or changes because the tenderer was not familiar with the contents of this Addendum.


A question has been received from potential tenderer about the subject Request for Proposals. The purpose of this Addendum to the Request for Proposals is to summarize the question and answer the information of all potential bidders.

Question #1:

Would a 0U (half height) vertical pdu (36.1 inches long) be acceptable?

Answer # 1:

No, the PDU must rack mountable in a **horizontal form factor**. Per the specifications, the PDU solution must include rack mount kits and must not exceed a maximum height of 2U per PDU in a horizontal form factor.



Tenderers are to acknowledge this Addendum by signing in the space provide below and enclosing a copy of this document with their Technical proposal.

All other terms and conditions of the Request for Proposals remain unchanged.			
Yours truly,			
Original signed by/			
Tunde Temidire Senior Procurement Officer Procurement and Vendor Relations			

RECEIPT ACKNOWLEDGED

Name of Company	_	
G!		
Signature		

Canadä