

SEE DRAWING / VOIR LE DESSIN E.308



DRAWING NOTES

1 TYPICAL
NEW FIRE ALARM PULL STATION TO BE MOUNTED AT 1200mm A.F.F.,
MEASURED FROM THE CENTRE OF THE MANUAL STATION, AS PER
CAN/ULC-S524, PARAGRAPH 8.1.1.

E N/A

5. TYPICAL
REPLACE EXISTING FLAME DETECTOR AND ADDRESSABLE MODULE. EXISTING
MOUNTING HEIGHT APPROXIMATELY 5 METERS A.F.F.

GENERAL NOTES

1	REFER TO DRAWING E.001 "EXISTING CONDUIT & WIRING."
2	NEW CONDUIT TO BE CONCEALED WHERE POSSIBLE.
3	LOCATE AND REPLACE EXISTING FAULT ISOLATION MODUL INCLUDING CO
	AND WIRING.