



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Fort Nelson 12 Residences Building Amélioration de l'enveloppe du bâtiment de 12 résidences à Fort Nelson	
Solicitation No. - N° de l'invitation EZ899-211939/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client	Date 2021-02-03
GETS Reference No. - N° de référence de SEAG PW-\$PWY-031-8909	
File No. - N° de dossier PWY-0-43172 (031)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Pacific Standard Time PST on - le 2021-02-11 Heure Normale du Pacifique HNP	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Leung, Janie	Buyer Id - Id de l'acheteur pwy031
Telephone No. - N° de téléphone (778) 919-3273 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: RCMP – Fort Nelson, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EZ899-211939/A

Amd. No. - N° de la modif.
002

Buyer ID - Id de l'acheteur
PWY031

Client Ref. No. - N° de réf. du client

File No. - N° du dossier
PWY-0-043172

CCC No./N° CCC - FMS No./N° VME

This Amendment 002 is raised to issue Addendum No. 2.

All other terms and conditions remain unchanged.

ADDENDUM #2

Date: Feb 2, 2021

Fort Nelson 12 Residences
Building Envelope Upgrade
Project No: R.109055.001

The following revisions supersede the information contained in the original drawings and specification issued for the above named project, and shall become part thereof. No consideration will be allowed for extras due to the contractor or any subcontractor not being familiar with this Addendum.

1.0 ARCHITECTURAL SPECIFICATIONS

1.1 Specification Section 07 46 46 Fiber Cement Siding System

Delete paragraph 2.1 in Addendum one and replace with the following:

2.1 MATERIALS

- .1 Fiber Cement Siding:
 - .1 Fiber Cement Siding.
 - .2 Meet ASTM C1186, Type A, Grade II.
 - .3 Formulated from Portland cement, ground sand, cellulose fibers, additives, and water; formed under pressure to required profile.
 - .4 Type: **Lap siding and trim**, factory painted.
 - .5 **Siding Width: 5.25" (133mm) with 4" (102mm) exposed, trim to be 3.5" (88.9mm)**
 - .6 Thickness: **5/16 inch (8mm) for lap siding, 3/4 inch (19mm) for trim.**
 - .7 Surface texture: **imitated wood grain texture.**
 - .8 Fire hazard classification: Maximum flame spread/smoke developed rating of 0/5, tested to ASTM E84.
 - .9 Combustibility; Noncombustible, tested to ASTM E136.
 - .10 Finish: ColorPlus factory-applied, baked on finish,
 - .1 Color 1: Night Gray
 - .2 Color 2: Deep Ocean
 - .3 **Color for all trims: standard white color**
 - .11 Departmental Representative will consider products which **will meet or exceed this performance specification**, and are similar in material, construction, thickness, color, texture, and overall quality.

2.0 QUESTIONS AND ANSWERS

Q1. Please confirm what third party testing is required as per section 04 45 00 Section 1.2 Independent Inspection Agencies?

A1. In Section 08 50 00 Windows Paragraph 1.4.5.1 and 1.6.1.1, it asked for “Submit test reports from approved independent testing laboratories, certifying compliance with specifications.” If there is no such test report available from the manufacturer, Contractor will retain a third part testing agent to perform such tests.

Q2. Fibre Cement Siding, Section 07 46 46, 2.1.10 indicates the colour to be Night Gray or Deep Ocean. The Artisan Collection only comes in primed and in 5/16” thick material. Please confirm if standard Hardie Lap Siding in Night Gray or Deep Ocean (Factory Finish) is acceptable in lieu of the Artisan Collection? Attached is the Artisan information sheets from JamesHardie.

A2. This is acceptable. Refer to item 1.1 in this addendum.

Q3. On some of the houses, the foundation has black weatherproofing that is asbestos-containing. Please confirm that the expectation is that we are not to abate/remove the black weatherproofing as it is being covered as per the drawing details?

A3. If the existing asbestos-containing material remain undisturbed, there is no need to abate. However, any disturbance to this asbestos-containing weatherproofing during removal of current board or installation of new board, must be performed as per specification.

Q4. Please also confirm that we are not to abate/remove the black vapour barrier mastic indicated throughout interior wall cavities?

A4. There is no scope of opening up the drywall or window sill board from the interior and replace any existing vapour barrier. If any of the existing vapour barrier remain undisturbed, it will not require abatement.

END OF ADDENDUM #2