



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada - Pacific  
Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> Fort Nelson 12 Residences Building Amélioration de l'enveloppe du bâtiment de 12 résidences à Fort Nelson	
<b>Solicitation No. - N° de l'invitation</b> EZ899-211939/A	<b>Amendment No. - N° modif.</b> 002
<b>Client Reference No. - N° de référence du client</b>	<b>Date</b> 2021-02-03
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-031-8909	
<b>File No. - N° de dossier</b> PWY-0-43172 (031)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> Pacific Standard Time PST <b>on - le 2021-02-11</b> Heure Normale du Pacifique HNP	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Leung, Janie	<b>Buyer Id - Id de l'acheteur</b> pwy031
<b>Telephone No. - N° de téléphone</b> (778) 919-3273 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> RCMP – Fort Nelson, BC	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

**Les documents français seront disponibles sur demande.**

This Amendment 002 is raised to issue Addendum No. 2.

**All other terms and conditions remain unchanged.**

## ADDENDUM #2

Date: Feb 2, 2021

Fort Nelson 12 Residences  
Building Envelope Upgrade  
Project No: R.109055.001

---

The following revisions supersede the information contained in the original drawings and specification issued for the above named project, and shall become part thereof. No consideration will be allowed for extras due to the contractor or any subcontractor not being familiar with this Addendum.

---

### **1.0 ARCHITECTURAL SPECIFICATIONS**

#### 1.1 Specification Section 07 46 46 Fiber Cement Siding System

Delete paragraph 2.1 in Addendum one and replace with the following:

##### **2.1 MATERIALS**

- .1 Fiber Cement Siding:
  - .1 Fiber Cement Siding.
  - .2 Meet ASTM C1186, Type A, Grade II.
  - .3 Formulated from Portland cement, ground sand, cellulose fibers, additives, and water; formed under pressure to required profile.
  - .4 Type: **Lap siding and trim**, factory painted.
  - .5 **Siding Width: 5.25" (133mm) with 4" (102mm) exposed, trim to be 3.5" (88.9mm)**
  - .6 Thickness: **5/16 inch (8mm) for lap siding, 3/4 inch (19mm) for trim.**
  - .7 Surface texture: **imitated wood grain texture.**
  - .8 Fire hazard classification: Maximum flame spread/smoke developed rating of 0/5, tested to ASTM E84.
  - .9 Combustibility; Noncombustible, tested to ASTM E136.
  - .10 Finish: ColorPlus factory-applied, baked on finish,
    - .1 Color 1: Night Gray
    - .2 Color 2: Deep Ocean
    - .3 **Color for all trims: standard white color**
  - .11 Departmental Representative will consider products which **will meet or exceed this performance specification**, and are similar in material, construction, thickness, color, texture, and overall quality.

### **2.0 QUESTIONS AND ANSWERS**

Q1. Please confirm what third party testing is required as per section 04 45 00 Section 1.2 Independent Inspection Agencies?

**A1. In Section 08 50 00 Windows Paragraph 1.4.5.1 and 1.6.1.1, it asked for “Submit test reports from approved independent testing laboratories, certifying compliance with specifications.” If there is no such test report available from the manufacturer, Contractor will retain a third part testing agent to perform such tests.**

Q2. Fibre Cement Siding, Section 07 46 46, 2.1.10 indicates the colour to be Night Gray or Deep Ocean. The Artisan Collection only comes in primed and in 5/16” thick material. Please confirm if standard Hardie Lap Siding in Night Gray or Deep Ocean (Factory Finish) is acceptable in lieu of the Artisan Collection? Attached is the Artisan information sheets from JamesHardie.

**A2. This is acceptable. Refer to item 1.1 in this addendum.**

Q3. On some of the houses, the foundation has black weatherproofing that is asbestos-containing. Please confirm that the expectation is that we are not to abate/remove the black weatherproofing as it is being covered as per the drawing details?

**A3. If the existing asbestos-containing material remain undisturbed, there is no need to abate. However, any disturbance to this asbestos-containing weatherproofing during removal of current board or installation of new board, must be performed as per specification.**

Q4. Please also confirm that we are not to abate/remove the black vapour barrier mastic indicated throughout interior wall cavities?

**A4. There is no scope of opening up the drywall or window sill board from the interior and replace any existing vapour barrier. If any of the existing vapour barrier remain undisturbed, it will not require abatement.**

END OF ADDENDUM #2