



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Fort Nelson 12 Residences Building Amélioration de l'enveloppe du bâtiment de 12 résidences à Fort Nelson	
Solicitation No. - N° de l'invitation EZ899-211939/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client	Date 2021-02-08
GETS Reference No. - N° de référence de SEAG PW-\$PWY-031-8909	
File No. - N° de dossier PWY-0-43172 (031)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Pacific Standard Time PST on - le 2021-02-11 Heure Normale du Pacifique HNP	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Leung, Janie	Buyer Id - Id de l'acheteur pwy031
Telephone No. - N° de téléphone (778) 919-3273 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: RCMP – Fort Nelson, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EZ899-211939/A

Amd. No. - N° de la modif.
004

Buyer ID - Id de l'acheteur
PWY031

Client Ref. No. - N° de réf. du client

File No. - N° du dossier
PWY-0-043172

CCC No./N° CCC - FMS No./N° VME

Les documents français seront disponibles sur demande.

This Amendment 004 is raised to issue Addendum No. 3.

All other terms and conditions remain unchanged.

ADDENDUM #3

Date: Feb 8, 2021

Fort Nelson 12 Residences
Building Envelope Upgrade
Project No: R.109055.001

The following revisions supersede the information contained in the original drawings and specification issued for the above named project, and shall become part thereof. No consideration will be allowed for extras due to the contractor or any subcontractor not being familiar with this Addendum.

1.0 ARCHITECTURAL SPECIFICATIONS

1.1 Specification Section 08 11 00 Metal Doors and Frames

Delete:

2.1 MATERIALS

.1 All exterior doors to be hot dipped galvanized with Z275 designation zinc coatings, and door frames to be wood frame. Interior doors and door frames to be zinc wiped galvanized; having zinc coating finish designation ZF075 to ASTM 525. Exterior and interior door face to be 18 gauge, factory painted.

.2 Reinforcement to CSA G40.20/G40.21, Type 44W, coating designation to ASTM A 653M, ZF75.

Add:

2.1 MATERIALS

.1 All exterior doors to be **galvanneal A60 designation zinc-iron alloy coatings**, and door frames to be wood frame. Exterior door face to be 18 gauge, factory painted.

.2 Reinforcement to CSA G40.20/G40.21, Type 44W. **Coating designation to ASTM A 653/A 653M, coating designation "A".**

2.0 CLARIFICATIONS

2.1 All exterior doors to be 18ga, A60 zinc coating, and with polyurethane core.

END OF ADDENDUM #3