



**RETURN BIDS TO:
RETOURNER LES SUBMISSION À :**

Parks Canada Agency Bid Receiving Unit
National Contracting Services

Bid Fax: 1-866-246-6893

Bid Email: soumissionsouest-bidswest@canada.ca

This is the only acceptable email address for responses to bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address may not be accepted.

The maximum email file size is 15 megabytes. PCA is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

**REVISION 004 TO A
INVITATION TO TENDER**

**RÉVISION 004 INVITATION À
SOUMISSIONER
DEMANDE D'OFFRES À
COMMANDES**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the offer remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'offre demeurent les mêmes.

Issuing Office - Bureau de distribution :
Parks Canada Agency
Calgary, AB

Title - Sujet : Field School Renovations – Yoho National Park	
Solicitation No. - N° de l'invitation : 5P420-20-0373/A	Date : February 18, 2021
Amendment No. - N° de modification : 004	
Client Reference No. - N° de référence du client :	
GETS Reference No. N° de référence de SEAG : PW-21-00943921	

Solicitation Closes - L'invitation prend fin : At - à : 2:00 PM On - le : February 19, 2021	Time Zone - Fuseau horaire MST
--	--

F.O.B. - F.A.B. : Plant - Usine : <input type="checkbox"/> Destination : <input checked="" type="checkbox"/> Other - Autre : <input checked="" type="checkbox"/>		
Address Enquiries to - Adresser toutes demande de renseignements à : Brinthan Balakumar		
Telephone No. - N° de telephone : 587-832-1894	Fax No. -N° de télécopieur : (866) 246-6893	Email Address – Courriel : Brinthan.balakumar@canada.ca
Destination of Goods, Services, and Construction - Destination des biens, services, et construction : See Herein		

TO BE COMPLETED BY THE BIDDER - À REMPLIR PAR LE SOUMISSIONNAIRE

Vendor/ Firm Name - Nom du fournisseur/ de l'entrepreneur :	
Address - Adresse :	
Telephone No. - N° de telephone :	Fax No. - N° de télécopieur :
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Signature :	Date :

Solicitation No. - N° de l'invitation :
5P420-20-0373/A

Amd. No. - N° de la modif. :
004

Contracting Authority - Autorité contractante :
Brinthan Balakumar

Client Ref. No. - N° de réf. du client :

Title – Titre :
Field School Renovations – Yoho National Park

Amendment 004

This amendment is raised to extend the solicitation end date and answer bidder questions.

A. Solicitation End Date

The closing date for tender 5P420-20-0373/A is extended from February 18, 2021 to **February 19, 2021 at 2:00PM Mountain Standard Time (MST)**.

A. Question and Answers

Q19) Are you expecting to have new flooring throughout, new flooring in rooms affected by wall demolition, or patch floors where demolition occurs?

A19) Disturbed or exposed flooring from demolition is to be patched as per project brief.

Q20) Is there a proposed layout and preferred building method (concrete or wood) for the required exterior access ramp to the new handicap access door?

A20) Exterior ramp is not included in scope of work, only doors.

Q21) Are you expecting a new ceiling in room 134 (Kitchen) or patch ceilings when walls are removed?

A21) Kitchen ceiling is to be patched to match existing

Q22) Scope calls for new ceilings in various room numbers. Are these the new room numbers or original room numbers?

A22) Ceiling reference numbers are as identified in new proposed layout.

Q23) Please confirm size of existing HWT and indicate same size or larger tank required

A23) Hot water tank is not part of project scope.

Q24) Please confirm whether existing hot water tank is to be replaced?

A24) See A23

Q25) How many hot water tanks currently exist in building?

A25) See A23

Q26) Is hot water tank propane or electric?

A26) Propane. See previous answer.

Q27) Is there old mechanical drawing that we might have access to?

A27) No additional reference documentation is available.

Q28) Where are the main trucks for the existing forced air system?

A28) Exact duct system layout is not known. Main delivery of forced air is below floors on both levels.

Q29) Are we replacing the furnaces?

A29) No.

Q30) How many Furnaces is there in each furnace room? What areas do they supply?

A30) There are 4 furnaces for the main mechanical room: 2 for main floor classrooms, 1 for activity area, 1 for upstairs. There are 2 furnaces in western portion of building mechanical room: One per floor.

Q31) The only Return air grills we could see was a large grill in what looks like the mechanical room wall and transfer grills on the interior doors. Is there any other return air in the building?

Solicitation No. - N° de l'invitation :
5P420-20-0373/A

Amd. No. - N° de la modif. :
004

Contracting Authority - Autorité contractante :
Brinthan Balakumar

Client Ref. No. - N° de réf. du client :

Title – Titre :
Field School Renovations – Yoho National Park

A31) Ductwork layout is not known.

Q32) Are we reusing the existing grills and registers? If so, do we have to match them with any new that we install?

A32) Refer to project brief. New products are to be used.

Q33) What kind, if any ventilation system is existing in the building? If nothing are we designing and installing a ventilation system (HRV)?

A33) Existing system is forced air including return air.

Q34) What rooms are being heated with the forced air system and which are being heated by other means?

A34) All rooms are forced air.

Q35) Is there an existing A/C system in the building? If not are we designing and installing one?

A35) Refer to amendment 002. No HRV. Exhaust fans are required.

Q36) Has there been a heat loss/gain calculation done for the building?

A36) No.

ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED