


- DRAWING NOTES**
- 1 TYPICAL: PROVIDE NEW LED LIGHT FIXTURE, TYPE AS INDICATED. REFER TO LIGHT FIXTURE SCHEDULE ON DRAWING E001 FOR ADDITIONAL INFORMATION.
  - 2 TYPICAL: PROVIDE NEW FIRE ALARM SPEAKER AS SHOWN. COORDINATE EXACT LOCATION ON SITE. CONNECT TO EXISTING FIRE ALARM SPEAKER CIRCUITS.
  - 3 TYPICAL: PROVIDE NEW SINGLE OR DOUBLE FACE PICTOGRAM STYLE EXIT SIGN AS SHOWN. CONNECT TO EXISTING EMERGENCY LIGHTING CIRCUIT FEEDING THE AREA.
  - 4 NEW LOCATION OF SPRINKLER DRY PIPE PRE-ACTION FIRE ALARM CONTROL PANEL. RECONNECT INITIATING AND SIGNAL CIRCUITS FROM RED SERVER ROOM ONLY, AND SPRINKLER SYSTEMS CONNECTIONS TO DRY PIPE SYSTEM.
  - 5 EXISTING LOW VOLTAGE LIGHTING CONTROL SYSTEM TO CONTROL ALL 347V LIGHTING CIRCUITS FROM PLP9A AND 120V CIRCUITS LP9A-2,4,6,8,10 THROUGH 347V RELAYS. PROVIDE NEW LOW VOLTAGE MASTER CONTROL OVERDRIVE SWITCHES AT FLOOR ENTRANCES. PROVIDE 0-10V DIMMERS FOR ALL GENERAL AREA LIGHTING 120V CIRCS. LP9A, 2,4,6,8,10.
  - 6 TYPICAL: PROVIDE 0-10V DIMMER SWITCHES FOR EACH FIXTURE TYPE AND WIRELESS VACANCY SENSOR WALL MOUNTED.



key plan  
 plan repère

Contractor to verify all dimensions & conditions on site and immediately notify the departmental representative.

revisions	description	date
5	RE - ISSUED FOR TENDER	2021-01-08
4	RE - ISSUED FOR TENDER	2020-03-12
3	ISSUED FOR TENDER	2019-12-04
2	ISSUED FOR 99% REVIEW	2019-05-07
1	ISSUED FOR 66% REVIEW	2019-04-23

A	B	C
detail no. du détail	location drawing no. sur dessin no.	drawing no. dessin no.

project  
**PSPC SWING SPACE 9TH FLOOR**  
 PDP1, 50 RUE VICTORIA

drawing  
**LIGHTING LAYOUT**

Designed By	WN	Conçu par
Date	MAR 2020	(yyyy/mm/dd)
Drawn By	LB	Dessiné par
Date	MAR 2020	(yyyy/mm/dd)
Reviewed By	RB	Examiné par
Date	MAR 2020	(yyyy/mm/dd)
Approved By	RB	Approuvé par
Date	MAR 2020	(yyyy/mm/dd)
Tender	FRANK RADKE	Soumission
Project Manager	Administrateur de projets	
Project no.	No. du projet	
	<b>R.097053</b>	
Drawing no.	No. du dessin	
	<b>E101</b>	

**1 NEW LIGHTING LAYOUT**  
 E101 1:75

