



- MECHANICAL DRAWING NOTES
- 1 PROVIDE NEW SPRINKLERS AS INDICATED. EXTEND EXISTING SPRINKLER PIPING AS REQUIRED.
 - 2 PROVIDE NEW SPRINKLER PIPING AS INDICATED.
 - 3 PROVIDE NEW SPRINKLERS INTO PHONE BOOTHS AS INDICATED, COORDINATE EXACT LOCATION PRIOR TO ROUGH-IN. EXTEND SPRINKLER PIPING AS REQUIRED. MINIMIZE NUMBER OF BRANCH INSIDE OF LIGHTING FIXTURE EXTENT.
 - 4 PROVIDE NEW UPRIGHT SPRINKLERS AS INDICATED C/W WIRE GUARD. EXTEND EXISTING SPRINKLER PIPING AS REQUIRED.
 - 5 RELOCATE EXISTING FIRE HOSE CABINET C/W ASSOCIATED ACCESSORIES AS INDICATED. EXTEND PIPING AS REQUIRED.
 - 6 RELOCATE EXISTING FIRE EXTINGUISHERS C/W ASSOCIATED MOUNTING BRACKET AS INDICATED.

Public Works and Government Services Canada

Travaux publics et services gouvernementaux Canada

Real Property Branch

Direction générale des biens immobiliers

GOODKEY WEEDMARK & ASSOCIATES LIMITED

1688 Woodward Dr.

Ottawa, Ontario

Canada K2C 3R8

GNAL PROJECT # 2017-446-1

Contractor to verify all dimensions & conditions on site and immediately notify the departmental representative.

5	RE - ISSUED FOR TENDER	2021-01-08
4	RE - ISSUED FOR TENDER	2020-03-12
3	ISSUED FOR TENDER	2019-12-04
2	ISSUED FOR 99% REVIEW	2019-05-07
1	ISSUED FOR 66% REVIEW	2019-04-23

revisions	description	date
A	A: detail no. du detail	A
C	B: location drawing no. sur dessin no.	B
	C: drawing no. dessin no.	C

project

projet

PSPC SWING SPACE
9TH FLOOR

PDP1, 50 RUE VICTORIA

drawing

dessin

MECHANICAL
9TH FLOOR
FIRE PROTECTION
NEW WORK

Designed By	S.HAMILTON / J.CHENG	Conçu par
Date	JAN 2021	(yyyy/mm/dd)
Drawn By	J.CHENG / P.AZDAJIC	Dessiné par
Date	JAN 2021	(yyyy/mm/dd)
Reviewed By	S.HAMILTON	Examiné par
Date	JAN 2021	(yyyy/mm/dd)
Approved By	S.HAMILTON	Approuvé par
Date	JAN 2021	(yyyy/mm/dd)
Tender	FRANK RADKE	Soumission
Project Manager	Administrateur de projets	
Project no.	No. du projet	
	R.097053	
Drawing no.	No. du dessin	
	M102	

PWGSC B1 (1000 x 707)

0 10 20mm 40 60 80 100 120 140 160 180 200mm