



- MECHANICAL DRAWING NOTES**
- 1 REMOVE EXISTING DUAL DUCT MIXING BOX (MB) & A/C UNIT (AC) C/W ASSOCIATED DUCTWORK, DIFFUSERS & WIRING AS INDICATED.
 - 2 DISCONNECT EXISTING WIRING FROM MIXING BOX DURING DEMOLITION.
 - 3 REMOVE EXISTING DIFFUSERS, GRILLES AND DUCTWORK AS INDICATED.
 - 4 REMOVE EXISTING TEMPERATURE SENSOR CONNECTED TO MIXING BOX IN CEILING SPACE OF FLOOR BELOW C/W ASSOCIATED WIRING. RETAIN FOR RELOCATION IN NEW CONSTRUCTION.
 - 5 REMOVE EXISTING MIXING BOX SERVING PERIMETER ZONE OF FLOOR ABOVE AS INDICATED.

Canada
 Public Works and Government Services Canada
 Travaux publics et services gouvernementaux Canada
 Real Property Branch
 Direction générale des biens immobiliers

Goodkey Weedmark Consulting Engineers
 GOODKEY WEEDMARK & ASSOCIATES LIMITED
 1688 Woodward Dr.
 Ottawa, Ontario
 Canada K2C 3R8 GWA PROJECT # 2017-446-1

seal/sceau

key plan
plan repère

Contractor to verify all dimensions & conditions on site and immediately notify the departmental representative.

revisions	description	date
5	RE - ISSUED FOR TENDER	2021-01-08
4	RE - ISSUED FOR TENDER	2020-03-12
3	ISSUED FOR TENDER	2019-12-04
2	ISSUED FOR 90% REVIEW	2019-05-07
1	ISSUED FOR 66% REVIEW	2019-04-23

A	A
C	B

A: detail no. du detail
 B: location drawing no. sur dessin no.
 C: drawing no. dessin no.

project / projet
PSPC SWING SPACE 9TH FLOOR
 PDP1, 50 RUE VICTORIA

drawing / dessin
MECHANICAL 9TH FLOOR HVAC DEMOLITION

Designed By	S.HAMILTON / J.CHENG	Conçu par
Date	JAN 2021	(yyyy/mm/dd)
Drawn By	J.CHENG / P.AZDAJIC	Dessiné par
Date	JAN 2021	(yyyy/mm/dd)
Reviewed By	S.HAMILTON	Examiné par
Date	JAN 2021	(yyyy/mm/dd)
Approved By	S.HAMILTON	Approuvé par
Date	JAN 2021	(yyyy/mm/dd)
Tender	FRANK RADKE	Submission
Project Manager	Administrateur de projets	
Project no.	No. du projet	
	R.097053	
Drawing no.	No. du dessin	
	M301	

MECHANICAL HVAC - DEMOLITION
 1 M301 1:75