



IRC Building Sciences Group

38 Antares Drive, Suite 1200
Ottawa, Ontario, K2E 7V2
Tel: 613.225.0693, Fax: 613.225.7331
Toll Free: 1.888.607.5245

Addendum No. 1

Project:	Structural Assessment w/ Design	Page No:	1 of 1
Facility:	Major Holland Armoury	Date:	February 2, 2021
Address:	2100 Walkley Ave, Ottawa, ON	IRC Ref. No:	EB18-082SP-17179
		Client Ref. No:	EP916-211492

Bidders to note and consider in their pricing, the following changes made to the Bid Documents by this Addendum issued by IRC Group prior to the Bid Closing. Acknowledge receipt of this Addendum on the Bid Form where indicated and submit signed copy of last page with Bid.

1.0 CLARIFICATIONS

Q1: Regarding the above noted solicitation, please provide the following information: Column repair details for Group B (plans start with group C)

A1: There is no detail repair for group B, Group B piers are in good conditions and they don't need repair. If question still not answered please take snap shot of the discrepancy you are referring to and attach it to your question.

Q2: Please clarify the "protective coat" shown on the repair details, is this meant to be a component of the one layer carbon fiber fabric, or another product entirely on top of that?

A2: There are two layers, one layer of carbon fiber and another layer of protective coats, if carbon fiber required, a protection coat is required. These apply for repair groups C and D.

End of Addendum No. 1