

PART 1 - GENERAL**1.1 RELATED REQUIREMENTS**

- .1 Not Used.

1.2 REFERENCE STANDARDS

- .1 Canadian General Standards Board (CGSB)
 - .1 CGSB 1.59-97, Alkyd Exterior Gloss Enamel.
 - .2 CAN/CGSB 1.189-00, Exterior Alkyd Primer for Wood.
- .2 CSA Group (CSA)
 - .1 CSA-O121-M1978(R2003), Douglas Fir Plywood.
- .3 Public Works Government Services Canada (PSPC) Standard Acquisition Clauses and Conditions (SACC)-ID: R0202D, Title: General Conditions 'C', In Effect as Of: May 14, 2004.

1.3 INSTALLATION AND REMOVAL

- .1 Provide temporary controls in order to execute Work expeditiously.
- .2 Remove from site all such work after use.

1.4 GUARD RAILS AND BARRICADES

- .1 Provide secure, rigid guard rails and barricades around deep excavations, open shafts, open stair wells, open edges of floors and roofs.
- .2 Provide as required by governing authorities.

1.5 WEATHER ENCLOSURES

- .1 Provide weather tight closures to unfinished door and window openings, tops of shafts and other openings in floors and roofs.
- .2 Close off floor areas where walls are not finished; seal off other openings; enclose building interior work for temporary heat.

1.6 DUST TIGHT SCREENS

- .1 When work is to be executed outside of temporary partitions, provide dust tight screens to localize dust generating activities, and for protection of workers, finished areas of Work and public.
- .2 Maintain and relocate protection until such work is complete.

1.7 TEMPORARY PARTITIONS

- .1 Build temporary partitions and temporary ceilings around the site with 1hr fire resistance, in accordance with the 2015 NFC, with the following materials:
 - .1 Gypsum board type X, 16 mm.
 - .2 Steel studs, 92 mm @ 610 mm o/c max, 25-gauge.

- .3 Acoustic and fireproof roxul insulation, 89 mm thick.
- .4 Gypsum board type X, 16 mm with taped joints, sanded, paint entire gypsum board (public side) (1 primer coat and 2 finish coats) colour to be selected by Consultant.
- .2 Provide access door and steel frame to be painted, with fire resistance equivalent to partition. Provide UL compliant hardware and a lockable lock.
- .3 Provide, as necessary, temporary lighting.
- .4 Protect floor and partitions located inside work limit.
- .5 Maintain temporary partitions and move them as necessary until the end of construction work. If necessary, repair finishes following removal.

1.8 PROTECTION OF BUILDING FINISHES

- .1 Provide protection for finished and partially finished building finishes and equipment during performance of Work.
- .2 Provide necessary screens, covers, and hoardings.
- .3 Confirm with Consultant locations and installation schedule (5) days prior to installation.
- .4 Be responsible for damage incurred due to lack of or improper protection.

1.9 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate waste materials for recycling.

PART 2 - PRODUCTS

2.1 NOT USED

- .1 Not Used.

PART 3 - EXECUTION

3.1 NOT USED

- .1 Not Used.

END OF SECTION
