



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Public Works and Government Services Canada
Canada Place/Place du Canada
10th Floor/10e étage
9700 Jasper Ave/9700 ave Jasper
Edmonton
Alberta
T5J 4C3
Bid Fax: (418) 566-6167

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

**Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
Canada Place / Place du Canada
10th Floor / 10e étage
9700 Jasper Ave / 9700 ave Jasper
Edmonton
Alberta
T5J 4C3

Title - Sujet SIU Upgrades - EIFW	
Solicitation No. - N° de l'invitation EW038-212139/A	Amendment No. - N° modif. 010
Client Reference No. - N° de référence du client CSC EW038-212139	Date 2021-02-26
GETS Reference No. - N° de référence de SEAG PW-\$PWU-201-11985	
File No. - N° de dossier PWU-0-43226 (201)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Mountain Standard Time MST on - le 2021-03-02 Heure Normale des Rocheuses HNR	
F.O.B. - F.A.B.	
Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ho (RPC), Hector	Buyer Id - Id de l'acheteur pww201
Telephone No. - N° de téléphone (780) 901-0989 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EW038-212139/A
Client Ref. No. - N° de réf. du client
CSC EW038-212139

Amd. No. - N° de la modif.
010
File No. - N° du dossier
PWU-0-43226

Buyer ID - Id de l'acheteur
pwu201
CCC No./N° CCC - FMS No./N° VME

24 February 2021
R.106942.001

ADDENDA No. 10
Page 1 of 2

ADDENDUM No. 10

This Addendum is issued prior to Bid due date to revise the Bid/Contract Documents and as such is part of those documents; value of all items shall be included in Bid. After acceptance of Bid, claims for costs will not be considered by reason of failure by Bidder to have read Addenda.

Q1: REFERRING TO DRAWING E5 - COPPER LIGHTING (TYPE 102), ARE THESE TO BE SUPPLIED BY CSC?

Response: Fixture Type 102 is to be supplied and installed by the GC in contract.

Q2: BASED ON THE ATTACHED PICTURE (TAKEN FROM ROOM S169), WILL THIS SIDEWALK BE AFFECTED BY THE NEW EXERCISE YARD? IF SO, CAN WE PLEASE GET THE DETAILS OF THE AFFECTED AREA?



Response: Existing sidewalk from Exit A from Building MNS should not be affected by the new Exterior Yard work. Existing concrete pad for demolition will be affected, and is noted on drawing D3.

Q3: IS THERE A PLAN/LAYOUT AVAILABLE FOR THE CONDUIT TRENCH MENTIONED ON DRAWING E5?

Response: Response: Refer to detail no.2 on drawing no. ES5 for underground conduit layout.

Q4: CAN THE CURRENT ACCESS CONTROL SYSTEM SOFTWARE AND VERSION ON SITE BE CONFIRMED? THE SPEC LISTS CCURE 9000, CONTINENTAL ACCESS CARD ACCESS 3000, AND CA4K IN SECTION 25 13 00.

Response: The facility will need to verify that the current information listed here is accurate: supplier for the access control system is Spalding Hardware Edmonton, with regional support from Jeff Mills. Current access control system is Continental Access Card 3000.

Q5: CAN THE DOOR HARDWARE FOR THE ACCESS CONTROLLED DOORS BE CLARIFIED? THE ES5, ES7, AND ES8 DRAWINGS AND SPEC SECTION 08 06 00 DOOR SCHEDULES FOR DOORS: S149, S170, S172, AND S174 ARE IN CONFLICT.

Response: Where a conflict between electronic security (ES) and architectural hardware exists, ES shall govern. The intent for these doors is to provide new heavy-duty commercial doors and frames OR reuse existing doors and frames, modifying as required and provide electronic security as noted on ES documents. No additional Automatic Door Openers are required by the facility.

For Door S174 **ADD** one delayed egress crash bar, the same as noted for door S172 and S149 in 08 71 00.

All intercom and door position sensor notes and requirements are on ESS documents.

Q6: IF WE AND/OR OUR PARTNERS CAN BE APPROVED VENDOR, WILL WE HAVE ACCESS TO ALL PASSWORD AS-BUILTS, AND INFORMATION NEEDED TO WORK WITH THE EXISTING DATABASE?

Response: Access to passwords and existing documentation will need to be coordinated with the departmental representative and facility.

END OF SECTION