



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Travaux publics et Services gouvernementaux
Canada

Voir dans le document/

See herein

NA

Québec

NA

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Travaux publics et Services gouvernementaux Canada
Place Bonaventure, portail Sud-Oue
800, rue de La Gauchetière Ouest
7^e étage, suite 7300
Montréal
Québec
H5A 1L6

Title - Sujet Furniture - CAT1 for ESDC	
Solicitation No. - N° de l'invitation EF932-212509/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client R.094883.600	Date 2021-03-04
GETS Reference No. - N° de référence de SEAG PW-SMTA-555-16087	
File No. - N° de dossier MTA-0-43307 (555)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Eastern Daylight Saving Time EDT on - le 2021-03-17 Heure Avancée de l'Est HAE	
F.O.B. - F.A.B. Specified Herein - Précisé dans les présentes Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input checked="" type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Carbonneau, Julie	Buyer Id - Id de l'acheteur mta555
Telephone No. - N° de téléphone (418) 929-6780 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: Voir doc	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date


AMENDMENT 002:

The purpose of this amendment is the following:

- 1) Answer questions received from the industry (4 to 7).
- 2) Amend the request for bid.

QUESTION 4:

Please confirm either base or ceiling electric feed for these panels:

**ANSWER 4:**

This panel zone will be fed through a baseboard feeding unit. We cannot use a feeding pole because of the proximity of the outside wall and a gypsum ceiling in this area. Feeding will then connect to the base.

QUESTION 5:

The legend says 4 duplex outlets while the drawing says 3. Please confirm the duplex's quantity per workstation.

IMPORTANT - ÉLECTRIFICATION DES ÉCRANS /
IMPORTANT - PANELS' ELECTRIFICATION

1-L'ÉLECTRIFICATION SERA INSTALLÉE EN DESSOUS DES SURFACES DE TRAVAIL.
ELECTRIFICATION WILL BE INSTALLED UNDER THE WORK SURFACE.

2-TOUTS LES POSTES DE L'AIRE OUVERTE AURONT 4 PRISES DUPLEX AU TOTAL
AINSI QUE DES PRISES VOIX/DATA SAUF INDICATION CONTRAIRE
ALL WORKSTATION IN THE OPEN AREA WILL HAVE 4 DUPLEX OUTLETS UNLESS OTHERWISE SPECIFIED

ANSWER 5:

We confirm 3 duplex outlets per workstation. The legend is wrong.

QUESTION 6:

Cat 1b item 2, you specify « attached to the panels » but the code says with « C » leg. Please modify the code GoCUID for 1bFFHREN24L42WNOLNY in order to obtain attached surfaces to the panels.

ANSWER 6:

We accept the GoCUID change for "1bFFHREN24L42WNOLNY" (see table 1 modified).

QUESTION 7:

Cat 1a, citizen's services zone. Please confirm that you want 66" high panels made of 36" base panels and 30" high overpanels.

ANSWER 7:

We confirm the 66" total height made of 36" base panels and 30" high overpanels.

DELETE Table 1 – Product table and INSERT this following:

Product Category: 1

Table 1 – Product Table

Section A - IU REQUIREMENT					Section B – SUPPLIER’S BID		
#	GoCUID	Description of Product (Additional product details may be inserted, if required as per 6B. 4.1 of the SA)	QTY	** Provide additional Information Yes/No	Supplier Part Number	Firm Unit Price \$	Extended Total [Qty x Price] \$
Category 1A							
1	Refer to Annex C and Floor Plans. Total QTY: 158						\$
Category 1B							
2	1bFFHREN24L42WNOLNY	24x42 Surfaces attached to the acoustical panels	3	no		\$	\$
3	1bCPSXXNXXL24XFRNNN	18” Frameless frosted glass intimacy panels Combined with some 24x36 panels	8	no			
4	1bCPSXXNXXL30XFRNNN	18” Frameless frosted glass intimacy panels Combined with some 30x36 panels	16	no			
5	1bCPSXXNXXL54XFRNNN	18” Frameless frosted glass intimacy panels Combined with some 54x36 panels	8	no			
**Provide additional information:							
Canada is requesting bidders to provide drawings and/or pictures including descriptive literature for these products with your bid submission.							
NSA products (must not exceed 30% of the firm quantity by category)							
The Supplier signs, and certifies that all the NSA products offered will conform to all specifications and meet the testing requirements detailed at Annex D.							
Section A - IU REQUIREMENT					Section B – SUPPLIER’S BID		
#	NSA Product(s) Description		QTY	** Provide additional Information Yes/No	Supplier Part Number	Firm Unit Price \$	Extended Total [Qty x Price] \$
6	18x30 Surfaces attached to the acoustical panels		4	no		\$	\$
					Product Total		\$

**** ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME****