



Procurement Hub – Ottawa Office,  
Station 9N089A, 9th Floor,  
200 Kent Street,  
Ottawa, Ontario K1A 0E6

**March 9, 2021**

**ADDENDUM NO. 2**

**Subject: ITT Invitation to Tender No. FP802-200292**

**Title: Construction of one (1) equipment shelter and one (1) generator building**

**Location: St. Lawrence, NL**

**Closing Date: March 11, 2021 @ 2:00 PM (EST)**

Dear Sir/Madam:

Further to the above-mentioned Invitation to Tender, this **Addendum #2** is to advise potential bidders of the following raised questions received to date and of an extension to the tender closing date:

To delete:

Solicitation Closing date: March 8, 2021 at 2:00 PM EST

To insert:

Solicitation Closing date: March 11, 2021 at 2:00 PM (EST)

1. Q: Is there an electrical site plan?

**A: Please see attached.**

2. Q: Where do we install the new drop pole?

**A: We can reuse the current drop pole but will need to run a new buried cable from the drop pole to the new Generator Building. (Approx. 50 ft.)**

3. Where does telephone service conduit get terminated?

**A: The telephone service will be terminated in the new Equipment trailer. (Approx. 70ft from drop pole, Buried cable)**

4. Q: Where is the existing power line in respect to site?

**A : Please see attached.**




5. Q: The unit heater in the equipment shed is shown to be connected to panel A in generator shed, is this correct?

A : Yes.

6. Q: All lighting and devices in the generator shed are shown to be connected to panel B in the equipment shed, is this correct?

A : Yes.

7. Q: What is the symbol  adjacent to the exterior door in generator shed?

A: This is the door alarm contact. Low voltage wire will need to be provided to that location. Contacts to be installed by owner.

8. Q: Who wired up and connects owner supplied equipment such as gas detector, generator, and other items?

A: Our in house electricians will complete this work.

9. Q: It is shown to install two compartments raceway in the generator shed but in the notes it says only in the equipment shed, which is correct?

A: Two compartment raceway to be installed in both the Generator and Equipment buildings.

Yours truly,

**Ginette Aliaga**

Procurement and Contracting Officer

Procurement Hub, Materiel and Procurement Services

Fisheries and Oceans Canada

200 Kent Street, 9N089A

Ottawa, ON, K1A 0E6

Email: [Ginette.AliagaGallo@dfo-mpo.gc.ca](mailto:Ginette.AliagaGallo@dfo-mpo.gc.ca)