



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

Bid Receiving - PWGSC / Réception des soumissions -  
TPSGC

11 Laurier St./11 rue Laurier

Place du Portage, Phase III

Core 0B2 / Noyau 0B2

Gatineau, Québec K1A 0S5

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

THIS DOCUMENT CONTAINS A SECURITY  
REQUIREMENT.

**Vendor/Firm Name and Address**

Raison sociale et adresse du  
fournisseur/de l'entrepreneur

**Issuing Office - Bureau de distribution**

Construction Services Division/Division des services de  
construction

140 O'Connor Street

140, rue O'Connor

Ontario

Ottawa

K1A 0S5

|  |   |
|--|---|
| <b>Title - Sujet</b> PSPC Swing Space, 50 Victoria   |   |
| <b>Solicitation No. - N° de l'invitation</b><br>EP916-201774/B   | <b>Amendment No. - N° modif.</b><br>001     |
| <b>Client Reference No. - N° de référence du client</b><br>20201774  | <b>Date</b><br>2021-03-09                   |
| <b>GETS Reference No. - N° de référence de SEAG</b><br>PW-\$\$\$FG-347-79753   |   |
| <b>File No. - N° de dossier</b><br>fg347.EP916-201774  | <b>CCC No./N° CCC - FMS No./N° VME</b>      |
| <b>Solicitation Closes - L'invitation prend fin</b><br><b>at - à 02:00 PM</b> Eastern Daylight Saving Time EDT<br><b>on - le 2021-03-16</b> Heure Avancée de l'Est HAE |   |
| <b>F.O.B. - F.A.B.</b>   |   |
| <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>                                 |   |
| <b>Address Enquiries to: - Adresser toutes questions à:</b><br>Boujenoui, Nabil  | <b>Buyer Id - Id de l'acheteur</b><br>fg347 |
| <b>Telephone No. - N° de téléphone</b><br>(613) 295-9356 ( )   | <b>FAX No. - N° de FAX</b><br>( ) -         |
| <b>Destination - of Goods, Services, and Construction:</b><br><b>Destination - des biens, services et construction:</b>  |   |

Instructions: See Herein

Instructions: Voir aux présentes

|  |  |
|--|--|
| <b>Delivery Required - Livraison exigée</b>  | <b>Delivery Offered - Livraison proposée</b> |
| <b>Vendor/Firm Name and Address</b><br><b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>   |  |
| <b>Telephone No. - N° de téléphone</b><br><b>Facsimile No. - N° de télécopieur</b>   |  |
| <b>Name and title of person authorized to sign on behalf of Vendor/Firm</b><br><b>(type or print)</b><br><b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b><br><b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b> |  |
| <b>Signature</b>   | <b>Date</b>                                  |

**The following changes to the tender documents are effective immediately. This amendment will form part of the contract documents.**

Amendment 001 is issued for the following:

- (1) Change the bid closing from Eastern Standard Time (EST) to Eastern Daylight Saving Time (EDT); and
- (2) Amend the Tender Document; and
- (3) Respond to Bidder Questions; and
- (4) Issue Addendum 001

---

**(1) Change the bid closing from Eastern Standard Time (EST) to Eastern Daylight Saving Time (EDT)**

**(2) Amend the Tender Document**

**(A) ITT document, page 8 of 23, R2710T GENERAL INSTRUCTIONS**

**DELETE** the following:

The following GI's are included by reference and are available at the following Web Site  
<https://buyandsell.gc.ca/policy-and-guidelines/standard-acquisition-clauses-and-conditions-manual/5/R/R2410T/18>

**REPLACE** with the following:

The following GI's are included by reference and are available at the following Web Site  
<https://buyandsell.gc.ca/policy-and-guidelines/standard-acquisition-clauses-and-conditions-manual/5/R/R2710T/22>

---

### **(3) Bidder Questions and Answers**

| <b>Item No.</b> | <b>QUESTION</b>   | <b>ANSWER</b>   |
|-----------------|---|---|
| 1               | Please provide site pictures in lieu of the site visit  | There are no pictures available at the moment   |
| 2               | Please advise for name and contact information of base building/mandatory subcontractors including but not limited to Security, Fire Protection, Data & Comms, Commissioning, BAS, Fire Alarm, etc. | Bid as per plans and specs- Refer to Section 01 33 00- 1.1.23 and refer to Addendum no. 001.  |
| 3               | Please advise for working hours and union requirements for this tender  | Bid as per plans and specs - Refer to Section 01 00 10.   |
| 4               | Please advise for access requirements   | Bid as per plans and specs - Refer to Section 01 00 10.   |
| 5               | Please advise for any assigned Cash Allowance   | Bid as per plans and specs - Refer to Section 01 00 10.   |
| 6               | Please confirm the bid submission procedure (Hand delivered to 11 Laurier Street, Gatineau, Quebec, K1A 1C9 by March 16, 2021 @ 2:00 P.M).  | Please refer to R2710T GI09 and SI05 of the ITT.  |
| 7               | Please confirm new furniture is NIC in this tender;   | Refer to Addendum no. 001.  |
| 8               | Please advise for A.V Scope of work;  | Bid as per plans and specs- The audio visual devices, installation of the devices, and audio visual cabling are not part of the general contractor scope and shall be tendered separately by the Government of Canada at a future date. |
| 9               | Please confirm existing furniture will be removed and reinstated by client;   | Bid as per plans and specs - Refer to Section 01 00 10- 1.12.1.   |
| 10              | Please advise for the name & contact information of mandatory or recommended Sound Masking subcontractor;   | Bid as per plans and specs- Refer to Section 27 51 19- 1.4.   |
| 11              | Please advise for door operator requirements;   | Bid as per plans and specs- Refer to ID-12, Door Hardware Schedule.   |
| 12              | Please confirm the specified digital locks for new lockers and Upholstery Fabrics to be supply & install by finish carpenters (Div 06);   | Bid as per plans and specs- Refer to ID-08, Millwork Legend and refer to Addendum no. 001.  |
| 13              | Please confirm all kitchen appliances will be supplied and installed by client;   | Bid as per plans and specs - Refer to ID-08.  |
| 14              | Please confirm no stainless steel countertop has been specified for this tender;  | Bid as per plans and specs- Ask for Clarification.  |
| 15              | Please advise for access to below floor & Basement area;  | Bid as per plans and specs - Refer to Section 01 00 10.   |
| 16              | Please advise for loading duct and freight elevator(s);   | Bid as per plans and specs – Refer to Sections 01 00 10 and 01 33 00.   |
| 17              | Please confirm all new screens will be supplied and installed by client;  | Bid as per plans and specs- The audio visual devices, installation of the devices, and audio visual cabling are not part of the general contractor scope and shall be tendered separately by the Government of Canada at a future date. |
| 18              | Please advise for any PA and Intercom scope of work;  | Bid as per plans and specs- The audio visual devices, installation of the devices, and audio visual cabling are not part of the general contractor scope and shall be tendered separately by the Government of Canada at                |

|    |   |  |
|----|---|--|
|    |   | a future date.   |
| 19 | Please advise for any window film scope of work;  | Bid as per plans and specs - Refer to ID-06, note 6.   |
| 20 | Please advise for any existing double layer partition wall and/ or flooring; and  | Bid as per plans and specs.  |
| 21 | Please advise for the name and contact information of mandatory or recommended Demountable partition walls supplier.  | Bid as per plans and specs- Refer to Section 10 22 19.   |
| 22 | I would like to know the start and end dates of the work for the project  | Refer to the Bid and Acceptance Form (BA), BA06 Construction Time  |
| 23 | There is a film specification in 08 80 00, but the wall finish architectural drawing states the film and signage will be handled in a different tender. We are certainly interested in quoting this tender once the information is available. Please review and advise.   | Bid as per plans and specs - Refer to ID-06, note 6.   |
| 24 | <p>Drq no ID 09</p> <ol style="list-style-type: none"> <li>1. Do you know which type of existing wall in Grid 2 K to J and typical.<br/>Is it CMU wall or Drywall ?</li> <li>2. same area : is there any sliding door or railing to be remove or no ?</li> </ol> <p>For your review and advise please find following enquires regarding the specified partitions types P6 &amp; P7 along with the attached cut sheets for an alternate Mountable Partition system (P5).</p> | <p>Bid as per plans and specs - Refer to ID-01, notes D1 and D7, ID-04 note 8 and refer to Addendum no. 001</p> <p>Bid as per plans and specs - Refer to Section 10 22 19 and ID-09.</p> |
| 25 | Work stations and floor furniture supplied and install under this contract or by others?  | Refer to Addendum no. 001.   |
| 26 | Lockers for personal items by system furniture or by us?  | Bid as per plans and specs- Refer to ID04 & ID-08 and refer to Addendum no. 001.   |
| 27 | For your review and approval for an alternate material. I have attached the technical data sheet of our Moodwall P4.  | Bid as per plans and specs - Refer to Section 10 22 19 and ID-09.  |

**ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME**

Solicitation No. - N° de l'invitation  
EP916-201774/B

Amd. No. - N° de la modif.  
001

Buyer ID - Id de l'acheteur  
fg347

Client Ref. No. - N° de réf. du client  
R.097053.012

File No. - N° du dossier  
FG347 / EP916-201774/B

CCC No./N° CCC - FMS No./N° VME

---

## **ADDENDUM 001**

**Date: March 8<sup>th</sup>, 2021**

**Addendum Number: 01**

**Project Number: R.097053**

The following changes in the bid documents are effective immediately.

This addendum will form part of the construction documents.

## **DRAWINGS**

### 1 ID-01 9<sup>th</sup> Floor Demolition Plan

.1 Delete note "D1 For total length and height of wall, existing wall is to be demolished, complete with any windows and window frames." and replace with "D1 for total length and height of wall, existing gypsum partition is to be demolished, complete with windows, window frames and doors."

### 2 ID-03 9<sup>th</sup> Floor New Furniture Plan

.1 Add Note #1 "Supply and install of new furniture not in scope."

### 3 ID-08 Details

.1 Add Note #1 "Locker digital locks to be supplied and installed by General Contractor."

## **SPECIFICATIONS**

### 1 01 33 00 Submittal Procedures

.1 Add article 1.1.23.4. "ADSS: Security."