

1 General

1.1 RELATED SECTIONS

- .1 Section 26 05 00 - Common Work Results - Electrical.

1.2 SUBMITTALS

- .1 Submit shop drawings and product data in accordance with Division 01 - General Requirements.

1.3 SYSTEM DESCRIPTION

- .1 Occupancy sensors to turn lighting on when entering a controlled area and off after the area is vacated.
- .2 Products sourced from a single manufacturer.

2 Products

2.1 TECHNOLOGY

- .1 Passive infrared (PIR) sensing systems are passive and react only to energy sources. They detect the difference between heat emitted by the human body and the background space.
- .2 Ultrasonic sensors (US) detect volumetric motion using the Doppler Principle to sense movement.
- .3 Dual technology (DT) sensors use both PIR and US technologies.

2.2 PASSIVE INFRARED AUTOMATIC WALL SWITCH

- .1 Advanced PIR technology wall switch to provide automatic control of lighting.
- .2 Programmable for either Manual-ON or Automatic-ON.
- .3 Digital time delay of 15 seconds to 30 minutes.
- .4 LED to indicate occupancy detection.
- .5 Adjustable unit sensitivity.
- .6 No minimum load requirement.
- .7 Compatible with all load types.
- .8 Five-year warranty.
- .9 Load: up to 800 W @ 120 V.
- .10 Minimum coverage: 180 deg. - 290 sq.ft.
- .11 Finish: White.

3 Execution

3.1 INSTALLATION

- .1 Obtain complete installation instructions from manufacturer prior to rough-in.
 - .2 Review sensor locations on site prior to rough-in and install in location within room that provides maximum sensor coverage but confines coverage to the room. Motion outside the room is not to activate lighting within the room.
 - .3 Locate occupancy sensors on vibration-free surfaces at least 1.8 m away from air vents.
 - .4 Wire sensors into circuits as indicated to control luminaires in the indicated areas of coverage.
 - .5 Program sensors and timers with time delay off set to 15 minutes.
 - .6 Occupancy sensors are to be individually adjusted in accordance with the manufacturer's recommendations for the specific room in which they are installed, taking into account room shape, size and usage.
 - .7 Test for acceptable operation.
-

- .8 Demonstrate operation to the satisfaction of the Departmental Representative.

3.2 COMMISSIONING

- .1 The system must be completely commissioned prior to interim inspection to verify optimum operation.
- .2 Sensors must be added or relocated and patterns adjusted as required to eliminate nuisance turning on/off of luminaires.

END OF SECTION