

## **1 General**

### **1.1 REFERENCES**

- .1 American National Standards Institute/American Society of Mechanical Engineers (ANSI/ASME)
  - .1 ANSI/ASME B31.1, Power Piping.
- .2 American Society for Testing and Materials International (ASTM)
  - .1 ASTM A125, Specification for Steel Springs, Helical, Heat-Treated.
  - .2 ASTM A307, Specification for Carbon Steel Bolts and Studs, 60,000 PSI Tensile Strength.
  - .3 ASTM A563, Specification for Carbon and Alloy Steel Nuts.
- .3 Factory Mutual (FM)
- .4 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
  - .1 Material Safety Data Sheets (MSDS).
- .5 Manufacturer's Standardization Society of the Valves and Fittings Industry (MSS)
  - .1 MSS SP58, Pipe Hangers and Supports - Materials, Design and Manufacture.
  - .2 ANSI/MSS SP69, Pipe Hangers and Supports - Selection and Application.
  - .3 MSS SP89, Pipe Hangers and Supports - Fabrication and Installation Practices.
- .6 Underwriter's Laboratories of Canada (ULC)

### **1.2 SYSTEM DESCRIPTION**

- .1 Design Requirements:
  - .1 Construct pipe hanger and support to manufacturer's recommendations utilizing manufacturer's regular production components, parts and assemblies.
  - .2 Base maximum load ratings on allowable stresses prescribed by ASME B31.1 or MSS SP58.
  - .3 Ensure that supports, guides, anchors do not transmit excessive quantities of heat to building structure.
  - .4 Design hangers and supports to support systems under conditions of operation, allow free expansion and contraction, prevent excessive stresses from being introduced into pipework or connected equipment.
  - .5 Provide for vertical adjustments after erection and during commissioning. Amount of adjustment in accordance with MSS SP58.
- .2 Performance Requirements:
  - .1 Design supports, platforms, cat walks, hangers, to withstand seismic events for locations as per the national building code.

### **1.3 SUBMITTALS**

- .1 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
  - .2 Shop drawings: submit drawings stamped and signed for approval by Departmental Representative.
  - .3 Submit shop drawings and product data for following items:
    - .1 Bases, hangers and supports.
    - .2 Connections to equipment and structure.
    - .3 Structural assemblies.
    - .4 Quality Assurance Submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
      - .1 Certification by manufacturer: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
      - .2 Instructions: submit manufacturers installation instruction.
-

- .1 Contractor will make available one (1) copy of systems suppliers installation instructions.

- .4 Closeout Submittals:

- .1 Provide maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

## 1.4 QUALITY ASSURANCE

- .1 Health and Safety:

- .1 Do construction occupational health and safety in accordance with Section 01 35 29.06 - Health and Safety Requirements.

## 2 Products

### 2.1 GENERAL

- .1 Fabricate hangers, supports and sway braces in accordance with ANSI B31.1 and MSS SP58 and MSS SP59.
- .2 Use components for intended design purpose only. Do not use for rigging or erection purposes.

### 2.2 PIPE HANGERS

- .1 Finishes:

- .1 Pipe hangers and supports: galvanized, painted with zinc-rich paint after manufacture.
  - .2 Use electro-plating galvanizing process or hot dipped galvanized process.
  - .3 Ensure steel hangers in contact with copper piping are copper plated or epoxy coated.

- .2 Shop and field-fabricated assemblies:

- .1 Trapeze hanger assemblies: MSS SP89.
  - .2 Steel brackets: MSS SP89.
  - .3 Sway braces for seismic restraint system: to MSS SP89.0

- .3 Hanger rods: threaded rod material to MSS SP58:

- .1 Ensure that hanger rods are subject to tensile loading only.
  - .2 Provide linkages where lateral or axial movement of pipework is anticipated.
  - .3 Do not use 22 mm or 28 mm rod.

- .4 Pipe attachments: material to MSS SP58:

- .1 Attachments for steel piping: carbon steel galvanized.
  - .2 Attachments for copper piping: copper plated black steel.
  - .3 Use insulation shields for hot pipework.
  - .4 Oversize pipe hangers and supports for insulated pipes.

- .5 Adjustable clevis: material to MSS SP69 UL listed, (FM approved where required) clevis bolt with nipple spacer and vertical adjustment nuts above and below clevis.

- .1 Ensure "U" has hole in bottom for riveting to insulation shields.

### 2.3 INSULATION PROTECTION SHIELDS

- .1 Insulated hot piping:

- .1 Curved plate 300 mm long, with edges turned up, carbon steel to comply with MSS SP69.

### 2.4 CONSTANT SUPPORT SPRING HANGERS

- .1 Springs: alloy steel to ASTM A125, shot peened, magnetic particle inspected, with +/-5% spring rate tolerance, tested for free height, spring rate, loaded height and provided with Certified Mill Test Report (CMTR).

- .2 Load adjustability: 10% minimum adjustability each side of calibrated load. Adjustment without special tools. Adjustments not to affect travel capabilities.
- .3 Provide upper and lower factory set travel stops.
- .4 Provide load adjustment scale for field adjustments.
- .5 Total travel to be actual travel + 20% . Difference between total travel and actual travel 25 mm minimum.
- .6 Individually calibrated scales on each side of support calibrated prior to shipment, complete with calibration record.

## **2.5 EQUIPMENT ANCHOR BOLTS AND TEMPLATES**

- .1 Provide templates to ensure accurate location of anchor bolts.

## **3 Execution**

### **3.1 MANUFACTURER'S INSTRUCTIONS**

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

### **3.2 INSTALLATION**

- .1 Install in accordance with:
  - .1 manufacturer's instructions and recommendations.
- .2 Vibration Control Devices:
  - .1 Install on piping systems at pumps, boilers and as indicated.
- .3 Clevis plates:
  - .1 Attach to concrete with four (4) minimum concrete inserts, one (1) at each corner.
- .4 Provide supplementary structural steelwork where structural bearings do not exist or where concrete inserts are not in correct locations.

### **3.3 HANGER SPACING**

- .1 Plumbing piping: to most stringent requirements of Canadian Plumbing Code.
- .2 Copper piping: up to NPS 1/2: every 1.5 m.
- .3 Within 300 mm of each elbow.

Max Pipe Size: NPS	Max Spacing Steel	Max Spacing Copper
up to 1-1/4	2.1m	1.8m
1-1/2	2.7m	2.4m
2	3.0m	2.7m

### **3.4 HANGER INSTALLATION**

- .1 Install hanger so that rod is vertical under operating conditions.
- .2 Adjust hangers to equalize load.
- .3 Support from structural members. Where structural bearing does not exist or inserts are not in suitable locations, provide supplementary structural steel members. Comprised of angle Iron or c-channel.

### **3.5 HORIZONTAL MOVEMENT**

- .1 Angularity of rod hanger resulting from horizontal movement of pipework from cold to hot position not to exceed 4 degrees from vertical.
  - .2 Where horizontal pipe movement is less than 13 mm, offset pipe hanger and support so that rod hanger is vertical in the hot position.
-

### **3.6 FINAL ADJUSTMENT**

- .1 Adjust hangers and supports:
  - .1 Ensure that rod is vertical under operating conditions.
  - .2 Equalize loads.
- .2 Adjustable clevis:
  - .1 Tighten hanger load nut securely to ensure proper hanger performance.
  - .2 Tighten upper nut after adjustment.
- .3 C-clamps:
  - .1 Follow manufacturer's recommended written instructions and torque values when tightening C-clamps to bottom flange of beam.

**END OF SECTION**

---