

1 General

1.1 RELATED SECTIONS

- .1 Section 23 05 29 - Hangers and Supports for HVAC Piping and Equipment.

1.2 REFERENCES

- .1 American Society of Heating, Refrigeration and Air Conditioning Engineers (ASHRAE)
 - .1 ANSI/ASHRAE/IESNA 90.1-, SI; Energy Standard for Buildings Except Low-Rise Residential Buildings.
- .2 American Society for Testing and Materials International, (ASTM)
 - .1 ASTM B209M-, Specification for Aluminum and Aluminum Alloy Sheet and Plate (Metric).
 - .2 ASTM C335-, Test Method for Steady State Heat Transfer Properties of Horizontal Pipe Insulation.
 - .3 ASTM C411-, Test Method for Hot-Surface Performance of High-Temperature Thermal Insulation.
 - .4 ASTM C449/C449M-, Standard Specification for Mineral Fiber-Hydraulic-Setting Thermal Insulating and Finishing Cement.
 - .5 ASTM C547-, Specification for Mineral Fiber Pipe Insulation.
 - .6 ASTM C553-, Specification for Mineral Fiber Blanket Thermal Insulation for Commercial and Industrial Applications.
 - .7 ASTM C612-, Specification for Mineral Fiber Block and Board Thermal Insulation.
 - .8 ASTM C795-, Specification for Thermal Insulation for Use with Austenitic Stainless Steel.
 - .9 ASTM C921-, Standard Specification for Thermal Insulation for Use in Contact with Austenitic Stainless Steel.
- .3 Canadian General Standards Board (CGSB)
 - .1 CGSB 51-GP-52Ma-, Vapour Barrier, Jacket and Facing Material for Pipe, Duct and Equipment Thermal Insulation.
- .4 Thermal Insulation Association of Canada (TIAC): National Insulation Standards.
- .5 Underwriters Laboratories of Canada (ULC)
 - .1 CAN/ULC-S102-, Surface Burning Characteristics of Building Materials and Assemblies.
 - .2 CAN/ULC-S701-, Thermal Insulation Polyotrene, Boards and Pipe Covering.

1.3 DEFINITIONS

- .1 For purposes of this section:
 - .1 "CONCEALED" - means any work which is installed in suspended ceilings (accessible or non-accessible), attics and non-accessible chases and furred-in spaces.
 - .2 "EXPOSED" - means any work which is not concealed in walls, shafts, or above accessible or non-accessible ceilings. Work behind doors, in closets, in cupboards, or under counters is considered exposed.
 - .3 Insulation systems - insulation material, fasteners, jackets, and other accessories.
 - .2 TIAC Codes:
 - .1 CRD: Commercial Round Ductwork,
 - .2 CRF: Commercial Rectangular Finish,
 - .3 CEF: Commercial Rigid Insulation External Application.
-

1.4 SHOP DRAWINGS

- .1 Submit shop drawings in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Submit for approval manufacturer's catalogue literature related to installation, fabrication for duct jointing recommendations.

1.5 SAMPLES

- .1 Submit samples in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Submit for approval: complete assembly of each type of insulation system, insulation, coating, and adhesive proposed. Mount sample on 12 mm plywood board. Affix typewritten label beneath sample indicating service.

1.6 MANUFACTURERS' INSTRUCTIONS

- .1 Submit manufacturer's installation instructions in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Installation instructions to include procedures used, and installation standards achieved.

1.7 QUALIFICATIONS

- .1 Installer: specialist in performing work of this section, and have at least 3 years successful experience in this size and type of project, qualified to TIAC standards.

1.8 DELIVERY, STORAGE AND HANDLING

- .1 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
- .2 Protect from weather and construction traffic.
- .3 Protect against damage from any source.
- .4 Store at temperatures and conditions recommended by manufacturer.

1.9 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 00 - Cleaning.
- .2 Remove from site and dispose of packaging materials at appropriate recycling facilities.
- .3 Collect and separate for disposal paper packaging material in appropriate on-site for recycling in accordance with Waste Management Plan.
- .4 Divert unused metal materials from landfill to metal recycling facility approved by Departmental Representative.
- .5 Divert unused adhesive material from landfill to official hazardous material collections site approved by Departmental Representative.
- .6 Do not dispose of unused adhesive materials into sewer systems, into lakes, streams, onto ground or in other locations where it will pose health or environmental hazard.

2 Products

2.1 FIRE AND SMOKE RATING

- .1 In accordance with CAN/ULC-S102:
 - .1 Maximum flame spread rating: 25.
 - .2 Maximum smoke developed rating: 50.

2.2 INSULATION

- .1 Mineral fibre: as specified includes glass fibre, rock wool, slag wool.
 - .2 Thermal conductivity ("k" factor) not to exceed specified values at 24°C mean temperature when tested in accordance with ASTM C335.
 - .3 TIAC Code C-1: Rigid mineral fibre board to ASTM C612, with factory applied vapour retarder jacket to CGSB 51-GP-52Ma (as scheduled in PART 3 of this Section).
 - .4 TIAC Code C-2: Mineral fibre blanket to ASTM C553 faced with factory applied vapour
-

retarder jacket to CGSB 51-GP-52Ma (as scheduled in PART 3 of this section).

- .1 Mineral fibre: to ASTM C553.
- .2 Jacket: to CGSB 51-GP-52Ma.
- .3 Maximum "k" factor: to ASTM C553.

2.3 JACKETS

- .1 Canvas:
 - .1 220 gm/m² cotton, plain weave, treated with dilute fire retardant lagging adhesive to ASTM C921.
- .2 Lagging adhesive: Compatible with insulation.
- .3 Self-adhesive weather barrier membranes shall be considered an alternate jacketing on all exterior ductwork, except high temperature ducts (i.e. grease exhaust ducts). Any exterior ductwork with this alternate shall be installed with 0% leakage.

2.4 ACCESSORIES

- .1 Vapour retarder lap adhesive:
 - .1 Water based, fire retardant type, compatible with insulation.
- .2 Indoor Vapour Retarder Finish:
 - .1 Vinyl emulsion type acrylic, compatible with insulation.
- .3 Insulating Cement: hydraulic setting on mineral wool, to ASTM C449.
- .4 ULC Listed Canvas Jacket:
 - .1 220 gm/m² cotton, plain weave, treated with dilute fire retardant lagging adhesive to ASTM C921.
- .5 Outdoor Vapour Retarder Mastic:
 - .1 Vinyl emulsion type acrylic, compatible with insulation.
 - .2 Reinforcing fabric: Fibrous glass, untreated 305 g/m².
- .6 Tape: self-adhesive, aluminum, reinforced, 75 mm wide minimum.
- .7 Contact adhesive: quick-setting
- .8 Canvas adhesive: washable.
- .9 Tie wire: 1.5 mm stainless steel.
- .10 Banding: 12 mm wide, 0.5 mm thick stainless steel.
- .11 Facing: 25 mm galvanized steel hexagonal wire mesh stitched on one face of insulation.
- .12 Fasteners: 4 mm diameter pins with 35 mm diameter clips, length to suit thickness of insulation.

3 Execution

3.1 PRE-INSTALLATION REQUIREMENTS

- .1 Pressure testing of ductwork systems complete, witnessed and certified.
- .2 Surfaces clean, dry, free from foreign material.

3.2 INSTALLATION

- .1 Install in accordance with TIAC National Standards.
- .2 Apply materials in accordance with manufacturers instructions and as indicated.
- .3 Use two layers with staggered joints when required nominal thickness exceeds 75 mm.
- .4 Maintain uninterrupted continuity and integrity of vapour retarder jacket and finishes.
 - .1 Hangers, supports to be outside vapour retarder jacket.
- .5 Supports, Hangers in accordance with Section 23 05 29 - Hangers and Supports for HVAC Piping and Equipment.
 - .1 Apply high compressive strength insulation where insulation may be compressed by weight of ductwork.

- .6 Fasteners: At 300 mm oc in horizontal and vertical directions, minimum two rows each side.

3.3 DUCTWORK INSULATION SCHEDULE

- .1 Insulation types and thickness: Conform to following Table:

	TIAC Code	Vapour Retarder	Thickness (mm)
Rectangular cold and dual temperature supply air ducts (concealed)	C-2	yes	100

- .1 Exposed round ducts 600 mm and larger, smaller sizes where subject to abuse:
 - .1 Use TIAC code C-1 insulation, scored to suit diameter of duct.

- .2 Finishes: Conform to following table:

	TIAC Code	
	Rectangular	Round
Indoor, concealed	None	none
Indoor, exposed within mechanical room	CRF/1	CRD/2
Indoor, exposed elsewhere	CRF/2	CRD/3

END OF SECTION