

1 General

1.1 RELATED SECTIONS

- .1 Section 26 05 00 – Common Work Results - Electrical.

1.2 REFERENCES

- .1 Canadian Standards Association (CSA)
 - .1 CAN/CSA C22.2 No. 4-89 (R2000), Enclosed Switches.

1.3 SUBMITTALS

- .1 Submit shop drawings and product data in accordance with Division 01 - General Requirements.

2 Products

2.1 DISCONNECT SWITCHES

- .1 Non-fusible, horsepower rated disconnect switch in CSA Enclosure type 1, to CAN/CSA C22.2 No. 4, size as indicated.
- .2 Provision for padlocking in on-off switch position by three locks.
- .3 Mechanically interlocked door to prevent opening when handle in ON position.
- .4 Fuseholders: suitable without adaptors, for type and size of fuse indicated.
- .5 Quick-make, quick-break action.
- .6 ON-OFF switch position indication on switch enclosure cover.

2.2 EQUIPMENT IDENTIFICATION

- .1 Provide equipment identification in accordance with Section 26 05 00 – Common Work Results - Electrical.
- .2 Indicate name of load controlled on size 4 nameplate.

3 Execution

3.1 INSTALLATION

- .1 Install disconnect switches complete with fuses as indicated.
- .2 In finished areas mount disconnect switches on top of flush mounted junction box with conduit nipple on its coverplate into the back of the switch.

END OF SECTION
