

1 General

1.1 REFERENCES

- .1 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
- .1 Material Safety Data Sheets (MSDS).

1.2 SUBMITTALS

- .1 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.
 - .1 Submit two copies of Workplace Hazardous Materials Information System (WHMIS) Material Safety Data Sheets (MSDS) in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
 - .2 Instructions: submit manufacturer's installation instructions.
 - .1 Contractor will make available one (1) copy of systems supplier's installation instructions.

1.3 QUALITY ASSURANCE

- .1 Health and Safety Requirements: do construction occupational health and safety in accordance with Section 01 35 29.06 - Health and Safety Requirements.

1.4 DELIVERY, STORAGE, AND HANDLING

- .1 Packing, shipping, handling and unloading:
 - .1 Deliver, store and handle in accordance with Section 01 61 00 - Common Product Requirements.
 - .2 Deliver, store and handle materials in accordance with manufacturer's written instructions.
- .2 Waste Management and Disposal:
 - .1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse in accordance with Section 01 74 00 - Cleaning.

2 Products

2.1 THERMOSTAT (HEATING AND COOLING, DEHUMIDIFICATION, HUMIDIFICATION)

- .1 Wall-mounted thermostat, for heating, cooling, heating-cooling, dehumidification, humidification with:
 - .1 Temperature setting range: 5°C to 30°C.
 - .2 Thermometer range: 5°C to 30°C.
 - .3 Markings in 10° increments.
 - .4 Differential temperature fixed at 1.1°C.
 - .5 2-stage heating control.
 - .6 Programmable 5 day - 2 day, night, and away scheduler.
 - .7 Humidity Setpoint Range: 30-70% RH.
 - .8 Humidity Read Range: 5%-95% RH(Non-Condensing).
 - .9 Humidification, cooling, dehumidification and Fan Contacts.

3 Execution

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.2 INSTALLATION

- .1 Install control devices.
- .2 On outside wall, mount thermostats on bracket or insulated pad 25 mm from exterior wall.
- .3 Install remote sensing device and capillary tube in metallic conduit. Conduit enclosing capillary tube must not touch heater or heating cable.

3.3 CLEANING

- .1 Proceed in accordance with Section 01 74 00 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION
