



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving - PWGSC / Réception des soumissions
→ TPSGC
10th Floor, 4900 Yonge Street /
10e étage, 4900 rue Yonge
Toronto
Ontario
M2N 6A6

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
Ontario Region
10th Floor, 4900 Yonge Street
Toronto
Ontario
M2N 6A6

Title - Sujet Loading Dock Renovation Rénovation de quai de chargement	
Solicitation No. - N° de l'invitation EQ754-211712/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client EQ754-211712	Date 2021-03-18
GETS Reference No. - N° de référence de SEAG PW-SPWL-012-2554	
File No. - N° de dossier PWL-0-43061 (012)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Eastern Daylight Saving Time EDT on - le 2021-03-30 Heure Avancée de l'Est HAE	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Caporusso, Mary	Buyer Id - Id de l'acheteur pwl012
Telephone No. - N° de téléphone (416) 318-8637 ()	FAX No. - N° de FAX (416) 952-1257
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: Correctional Services Canada (CSC) 330-338 Keele St. Toronto, Ontario	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EQ754-211712/A

Amd. No. - N° de la modif.
002

Buyer ID - Id de l'acheteur
pwl012

Client Ref. No. - N° de réf. du client
R.083503.001

File No. - N° du dossier
PWL-0-43061

CCC No./N° CCC - FMS No./N° VME

Solicitation Amendment No. 002 is issued to provide the following:

1. Extension to the bid closing date.

Extension of Time

Notice is hereby given that the closing date for reception of tenders previously due March 23, 2021, is extended to March 30, 2021 at 14:00 hours.

2. Questions and Answers (attached).

UNCLASSIFIED - NON CLASSIFIÉ

SI02 ENQUIRIES DURING THE SOLICITATION PERIOD

1. Enquiries regarding this bid must be submitted in writing to the Contracting Authority named on the Invitation to Tender - Page 1 at e-mail address mary.caporusso@tpsgc-pwgsc.gc.ca **Except for the approval of alternative materials as described in GI15 of R2710T, enquiries should be received no later than 7 business days prior to the date set for solicitation closing to allow sufficient time to provide a response. Enquiries received after that time may result in an answer NOT being provided.**
2. To ensure consistency and quality of the information provided to Bidders, PWGSC will examine the content of the enquiry and will decide whether to issue an amendment.
3. All enquiries and other communications related to this bid sent throughout the solicitation period must be directed ONLY to the Contracting Authority named in paragraph 1. Above. Failure to comply with this requirement may result in the bid being declared non-compliant.

Questions and Answers

Q29. For Occupancy Sensors – What is the quantity & brand with Catalogue Number?

A29. Remove requirement for occupancy sensing. Lighting to be switched by toggle switches as shown on layout. Revise note O1 as follows:

Supply and Install new pendant linear 4' led lights as per Luminaire schedule. Extend the conduits and wiring as required. The mounting height to be same as existing, add new 20A-1P breaker in panel 1B for lighting circuit as required.

Q30. What is the Panel 1B Type and brand?

A30. Panel box: NO 4842C – Max 255A, 240V – 48V

Q31. What is the remote head brand & Catalogue Number?

A31. Remote head is to be cleaned and re-installed.

Q32. Please provide manufacture make and model number with the performance rating for the existing radiator. If there's a preferred alternate radiator, please provide a make and model.

A32. Contractor to propose an alternate available radiator for approval.

Q33. When can the work start?

A33. April 2021.

Q34. Can an extension to closing date be provided to March 30, 2021, 14:00 hours?

A34. Yes an extension has been granted, please refer to Solicitation Amendment No. 002.