



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving - PWGSC / Réception des soumissions -
TPSGC

11 Laurier St./11 rue Laurier

Place du Portage, Phase III

Core 0B2 / Noyau 0B2

Gatineau, Québec K1A 0S5

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

THIS DOCUMENT CONTAINS A SECURITY
REQUIREMENT.

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Construction Services Division/Division des services de
construction

140 O'Connor Street

140, rue O'Connor

Ontario

Ottawa

K1A 0S5

Title - Sujet PSPC Swing Space, 50 Victoria	
Solicitation No. - N° de l'invitation EP916-201774/B	Amendment No. - N° modif. 005
Client Reference No. - N° de référence du client 20201774	Date 2021-03-22
GETS Reference No. - N° de référence de SEAG PW-\$\$\$FG-347-79753	
File No. - N° de dossier fg347.EP916-201774	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Eastern Daylight Saving Time EDT on - le 2021-03-30 Heure Avancée de l'Est HAE	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Boujenoui, Nabil	Buyer Id - Id de l'acheteur fg347
Telephone No. - N° de téléphone (613) 295-9356 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

The following changes to the tender documents are effective immediately. This amendment will form part of the contract documents.

Amendment 005 is issued for the following:

- (1) Provide drawing E303/R1 to scale; and
- (2) Provide the correct response to Question 52 in Amendment 004; and
- (3) Respond to Bidder Questions; and
- (4) Issue Addendum 003

(1) Provide drawing E303/R1 to scale

Refer to section Attachments on Buy and Sell, EP916-201774 Amendment-Modification 005.

(2) Provide the correct response to Question 52 in Amendment 004

Answer: Refer to Addendum no. 002 and Section 03 35 00- 1.5.6., 1.6.7., and 3.1

(3) Bidder Questions and Answers

Item No.	QUESTION	ANSWER
59	item 6 of Addenda 2 indicates "delete drawing E303. Replace with drawing E303/R1". This drawing has been shrunk down to fit into an 8-1/2 x 11" page size. That being said, the drawing provided in addenda no. 2 is not to scale. Please provide a drawing to scale.	Refer to Amendment 005, Item 1

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME

Solicitation No. - N° de l'invitation
EP916-201774/B

Amd. No. - N° de la modif.
005

Buyer ID - Id de l'acheteur
fg347

Client Ref. No. - N° de réf. du client
R.097053.012

File No. - N° du dossier
FG347 / EP916-201774/B

CCC No./N° CCC - FMS No./N° VME

ADDENDUM 003

Date: March 19th, 2021

Addendum Number: 03

Project Number: R.097053

The following changes in the bid documents are effective immediately.

This addendum will form part of the construction documents.

DRAWINGS

1 ID-01 9th Floor Demolition Plan

.1 Delete drawing ID-01. Replace with: Drawing ID-01/R1 Attached.

.2 Delete Drawing note "D4- Existing ramp to be demolished. Complete with handrails." and replace with "D4- Demolish entire existing metal raised floor system and anti-static floor tiles. Complete with floor ramp with black rubber flooring and wall mounted metal handrails."

.3 Delete drawing note "D5- Existing stairs and handrails to be demolished." And replace with "D5- Demolish entire existing metal raised floor system and anti-static floor tiles. Complete with stair assembly, rubber treads and wall mounted metal handrails."