

**Amendement 003**

**Fuel Storage System Upgrades  
Terra Nova National Park (TNNP) NL**

**EA003-211642/A**

\*\*\*\*\*  
THE FOLLOWING AMENDMENT TO THE TENDER DOCUMENTS IS EFFECTIVE IMMEDIATELY. THE AMENDMENT  
SHALL FORM A PART OF THE CONTRACT DOCUMENTS.  
\*\*\*\*\*

**Addendum NO2**

**Questions and Answers:**

**Question#1: With respect to the new Light Pole and Fixture, electrical suppliers have asked what voltage is required for this light and the lumen output.**

**Question #2: Can you provide a spec number for the pole light at the compound?**

Answer #1 and #2: The area light is required to be 120VAC, with an output of 3000 lumens. Acceptable material is Cree Lighting RSWS-B-HT-3ME-3L-27K8-UL-BZ-N or equal.

By submission of its tender, the Tenderer confirms that it has read and understands the requirements expressed in all addenda and has included all costs of these requirements in its Total Tender Amount.

All other terms & conditions remain unchanged.

\*\*\*\*\*