

Amendment 002 is raised to revise ANNEX "A" – STATEMENT OF WORK and ANNEX "A1" – COMPLIANCE MATRIX.

ANNEX "A" – STATEMENT OF WORK

REMOVE:

4.1.4.1 – The UPS must include AC power input cables, terminated for a NEMA 5-15 or 5-20 receptacle.

REPLACE WITH:

4.1.4.1 – The UPS must include AC power input cables, terminated for a NEMA 5-15.

ANNEX "A1" – COMPLIANCE MATRIX

REMOVE:

4.1.4.1 – The UPS must include AC power input cables, terminated for a NEMA 5-15 or 5-20 receptacle.

REPLACE WITH:

4.1.4.1 – The UPS must include AC power input cables, terminated for a NEMA 5-15.

All other terms of this solicitation remain the same.