



Fisheries and Oceans Canada
ADDENDUM no. 1
March 26, 2021

F5211-200673A: Auditorium accessibility – Maurice Lamontagne Institute

This addendum is being issued to answer questions related to tender F5211-200673A as follows:

Questions and Answers

Question #1:

Section 01 73 03, 1.3.2 Please specify the normal hours of operation or your desired schedule for work that may generate noise, odors and vibrations.

Answer #1:

After 4 p.m.

Question #2:

Section 03 30 00, 2.1.1.1 What does the data in brackets mean (+ 5 Mpa OR divided by 5 Mpa)?

Answer #2:

We should read $\pm 5\text{MPa}$.

Question #3:

In order to speed up the duration of the site, a flooring subcontractor told me that a vapor barrier should be put on the concrete ideally, Section 09 69 10 does not mention it?

Answer #3:

Indeed, a vapor barrier coating should be specified. It prevents moisture from escaping the concrete during curing. We can produce an addendum on this subject.*

Please refer to document F5211-200673A - Addenda A-01 in the attachments section.

Question #4:

Does the sealant specified in section 03 30 00 act as a vapor barrier, according to the same subcontractor, this sealant will not really be there when it has done its preparation?

Answer #4:

It is not a sealant for installing flooring.

All other terms and conditions remain the same.