

Amendment 002

**New Booster Station Electrical Room
Wabush, Airprot
Wabush, Newfoundland**

EC363-212224/A

THE FOLLOWING AMENDMENT TO THE TENDER DOCUMENTS IS EFFECTIVE IMMEDIATELY.
THE AMENDMENT SHALL FORM A PART OF THE CONTRACT DOCUMENTS.

Addendum #1

Specifications:

Reference Specification Section 26 32 13.01 – Power Generation Diesel, Part 3 - Field Quality Control

Add the following new item under section 3.1;

.10 As per NFPA 20-2016, item 9.6.2.2 as part of the Standard for the Installation of Stationary Pumps for Fire Protection indicates that the power sources shall continue to produce and provide power without the shutdown for any alarms, warnings, or failed sensors except for the overspeed shutdown. Generator contractor shall modify the current parameters within the generator controller to prevent the generator from shutting down due to any alarms on the unit with the exemption of the Overspeed fault to satisfy the requirement of the NFPA 20 standard. The contractor shall configure these parameters and demonstrate these during the generator testing.

By submission of its tender, the Tenderer confirms that it has read and understands the requirements expressed in all addenda and has included all costs of these requirements in its Total Tender Amount.

All other terms & conditions remain unchanged.
