



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Public Works and Government Services Canada
Canada Place/Place du Canada
10th Floor/10e étage
9700 Jasper Ave/9700 ave Jasper
Edmonton
Alberta
T5J 4C3
Bid Fax: (418) 566-6167

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
Canada Place / Place du Canada
10th Floor / 10e étage
9700 Jasper Ave / 9700 ave Jasper
Edmonton
Alberta
T5J 4C3

Title - Sujet AHU Replacement Air Handling Unit Replacement	
Solicitation No. - N° de l'invitation EP922-212716/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client PSPC EP922-212716	Date 2021-04-06
GETS Reference No. - N° de référence de SEAG PW-SPWU-004-12029	
File No. - N° de dossier PWU-0-43250 (183)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Mountain Daylight Saving Time MDT on - le 2021-04-13 Heure Avancée des Rocheuses HAR	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Espedido, Karielen K.	Buyer Id - Id de l'acheteur pwu183
Telephone No. - N° de téléphone (780) 231-4719 ()	FAX No. - N° de FAX (418) 566-6167
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This amendment has been raised with the following changes:

AMENDMENT #002:

On page 4 of 23, the email on SI02 #1 is revised as follows:

SI02 ENQUIRIES DURING THE SOLICITATION PERIOD

1. Enquiries regarding this bid must be submitted in writing to the Contracting Authority named on the Invitation to Tender - Page 1 at e-mail address karieleenkae.espedido@tpsgc-pwgsc.gc.ca. Except for the approval of alternative materials as described in GI15 of R2710T, enquiries should be received no later than 5 business days prior to the date set for solicitation closing to allow sufficient time to provide a response. Enquiries received after that time may result in an answer NOT being provided.

ADDENDUM #002:

BIDDERS' QUESTIONS & ANSWERS:

Q1: Can we remove the old AHU units all together or we should do it in stages? If in stages can you give me an idea of how many stages are allowed, to figure out the lifting cost?

A1: Although PSPC/CSC cannot dictate to the contractor the removal plan. It is preferred not to remove all units at once as this will render the facility vulnerable to outside temperature changes. That also depends on the location and installation schedule for the replacement units.

Q2: Can we use the building's washroom facilities or we have to allow for a site sanitary facility?

A2: The contractor should make arrangements for their own sanitary facilities onsite i.e. Porta Potties.

Q3: I also wanted to submit a Request for Equals (RFE) for our custom equipment manufacturer, Dynamic Air Technology (aka DAT), as an alternative.

A3: We will not accept this request as an alternative.

END OF AMENDMENT