



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada - Pacific  
Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> Generator Upgrade Prince Rupert Hanger Generator Upgrade	
<b>Solicitation No. - N° de l'invitation</b> EZ899-211720/A	<b>Amendment No. - N° modif.</b> 001
<b>Client Reference No. - N° de référence du client</b>	<b>Date</b> 2021-04-08
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-039-8946	
<b>File No. - N° de dossier</b> PWY-0-43225 (039)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> Pacific Daylight Saving Time PDT <b>on - le 2021-04-15</b> Heure Avancée du Pacifique HAP	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Park (PWY), Isabell	<b>Buyer Id - Id de l'acheteur</b> pwy039
<b>Telephone No. - N° de téléphone</b> (604) 365-0073 ( )	<b>FAX No. - N° de FAX</b> ( ) -
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> RCMP – Prince Rupert, BC	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
EZ899-211720/A

Amd. No. - N° de la modif.  
001

Buyer ID - Id de l'acheteur  
pwy039

Client Ref. No. - N° de réf. du client  
XXXXX

File No. - N° du dossier  
XXXXXXXXXXXXX

CCC No./N° CCC - FMS No./N° VME  
XXXXXXXXXXXXX

---

**Les documents français seront disponibles sur demande.**

**Amendment 001**

This amendment is raised to issue Addendum 01.

Addendum #1 dated 2021-04-07 attached

All other terms and conditions remain unchanged.

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

---

**.1 Drawings**

**.1 Drawing E-002 – Electrical Plan and Single Line Diagram**

- .1 Revise:** Keynote #12 to read: "Generator to be c/w with an LED light kit sufficient to illuminate generator equipment inside the enclosure access door. The light shall be operated by door switches."

**.2 Specifications**

**.1 Section 26 32 14 – Diesel Generators (Outdoors)**

- .1 Delete:** Sentence 1.1.6

**.3 Responses (R) to Questions (Q) Received:**

**Q.1** Do you know if the Government is supplying the equipment? As in the generator and the transfer switch, or do a source that from the generator manufacturer (Finning)?

**R.1** *As clearly stated in tender documents, all equipment and material for completion of the construction is to be provided by the Contractor.*

**Q.2** We are Custom Power Generation and we represent Blue Star Power Systems in Western Canada.

Custom Power Generation is Western Canadian based with offices in Vancouver, Calgary and Edmonton – with technicians throughout BC and Alberta. We are servicing generators for many municipalities and major customers (CP Rail, Shaw Cable, BCIT, City of Surrey to name a few). We have provided generators for many projects in Western Canada – including some RCMP projects in Alberta (Coaldale, Innisfail, Red Deer).

Blue Star Power Systems is a major generator manufacturer based in Mankato, MN in their 85,000 square foot purpose-built facility. Blue Star generators are CSA and UL-2200 certified – as well as seismic certified to IBC 2018 standards.

I have attached Blue Star's PD50-01 generator spec sheet – which is the unit we'd quote for the Prince Rupert RCMP project. Please let me know if any further information is required to help our case.

**R.2** *The generator that will be provided by the Contractor shall meet or exceed the requirements included in Specification Section 26 32 14. See also .2 of this Addendum.*

**END OF ADDENDUM No. 1**

---