



**RETURN BIDS TO:  
RETOURNER LES SUBMISSION À :**

Parks Canada Agency Bid Receiving Unit  
National Contracting Services

**Bid Fax:** 1-866-246-6893

**Bid Email:** [soumissionsouest-bidswest@canada.ca](mailto:soumissionsouest-bidswest@canada.ca)

This is the only acceptable email address for responses to bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address will not be accepted.

The maximum email file size is 15 megabytes. Parks Canada Agency (PCA) is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

**REVISION 003 TO A  
INVITATION TO TENDER**

**RÉVISION 003 À UNE  
INVITATION À SOUMISSIONNER  
DEMANDE D'OFFRES À  
COMMANDES**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Offer remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'offre demeurent les mêmes.

**Issuing Office - Bureau de distribution :**  
Parks Canada Agency  
Calgary, AB

<b>Title - Sujet :</b> East Gate Landslide Check Dams – Glacier National Park	
<b>Solicitation No. - N° de l'invitation :</b> 5P420-20-0511/A	<b>Date :</b> April 12, 2021
<b>Amendment No. - N° de modification :</b> 003	
<b>Client Reference No. - N° de référence du client :</b> 566	
<b>GETS Reference No.   N° de référence de SEAG :</b> PW-21-00950893	

<b>Solicitation Closes - L'invitation prend fin :</b> <b>At - à :</b> 2:00 PM <b>On - le :</b> April 15, 2021	<b>Time Zone - Fuseau horaire</b> MDT-HAR
---	--

**F.O.B. - F.A.B. :**  
**Plant - Usine :**     **Destination :**     **Other - Autre :**

**Address Enquiries to - Adresser toutes demande de renseignements à :** Christine LeClerc

<b>Telephone No. - N° de telephone :</b> (403) 763-0151	<b>Fax No. -N° de télécopieur :</b> (866) 246-6893	<b>Email Address – Couriel :</b> <a href="mailto:christine.leclerc@canada.ca">christine.leclerc@canada.ca</a>
--	---	--

**Destination of Goods, Services, and Construction - Destination des biens, services, et construction :**  
See Herein – Voir ci-haut

**TO BE COMPLETED BY THE BIDDER - À REMPLIR PAR LE SOUMISSIONNAIRE**

<b>Vendor/ Firm Name - Nom du fournisseur/ de l'entrepreneur :</b>	
<b>Address - Adresse :</b>	
<b>Telephone No. - N° de telephone :</b>	<b>Fax No. - N° de télécopieur :</b>
<b>Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur</b>	
<b>Signature :</b>	<b>Date :</b>

## **Amendment 003**

This amendment is being raised to distribute questions and answers.

### **A. Questions and Answers**

**Q27:** Does the access road include the path to the check dams? Can aerial pictures of previous contractors site layout be provided for reference purposes only?

**A27:** Refer to Section 31 53 13 – Log Crib Check Dams, Clause 1.1 for definition of the access road limits. Aerial pictures of the previous site layout are not available.

**Q28:** Will imported gravel be required for site access?

**A28:** Site access is the responsibility of the Contractor. Historically, imported gravel has not been used.

**Q29:** There is verbiage of stockpiling catchment cleanout material and placing material. Does this contract include the embankment placement and culvert install? if so, can additional line items be made to include this scope?

**A29:** No. Catchment cleanout material is to be stockpiled at the East Gate Storage Site as directed by the Departmental Representative.

**Q30:** What will be done with the organic matter that is sorted out of the embankment material? Is there a dump area for this material or will it be shipped to a landfill site? Can an additional line item be made for this?

**A30:** Organic soil (overburden) is not expected. Organic woody debris are to be stockpiled as per Section 31 24 13 – Catchment Cleanout.

**Q31:** Can articulated rock trucks be used to ship the material across the road and along the road shoulder to the allocated dump area?

**A31:** Yes, refer to Section 01 14 00 – Work Restrictions, Clause 1.11.1.

**Q32:** What is to be done with the saturated materials or considered unsuitable? If this need to be trucked to a landfill, can additional line items be made for this scope?

**A32:** Unsuitable material will be stockpiled at the East Gate Storage Site.

**Q33:** Is there a performance bond required for this project? Only requirements we can see is a bid security.

**A33:** Bid security is required at the time of closing, the awarded bidder will need to provide contract security which can be in the form of performance and labour and material bonds. Refer to R2890D GC9 Contract Security.

**Q34:** Can a 1-week extension to the closing date be made?

**A34:** Parks Canada has considered this request and determined that the closing date will remain unchanged.

**ALL OTHER TERMS & CONDITIONS REMAIN UNCHANGED**