



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet CCG SAR Crew Residence Construction CCG SAR Crew Residence Construction and Float Services	
Solicitation No. - N° de l'invitation F1700-204710/A	Amendment No. - N° modif. 007
Client Reference No. - N° de référence du client F1700-204710	Date 2021-04-15
GETS Reference No. - N° de référence de SEAG PW-SPWY-038-8931	
File No. - N° de dossier PWY-0-43162 (031)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Pacific Daylight Saving Time PDT on - le 2021-04-29 Heure Avancée du Pacifique HAP	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Costa (PWY), Michaela	Buyer Id - Id de l'acheteur pwy031
Telephone No. - N° de téléphone (236) 888-7800 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO – Hartley Bay, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation. - N° de l'off. à comm.
F1700-204710/A

Amd. No. - N° de la modif.
007

Buyer ID - Id de l'acheteur
PWY031

Client Ref. No. - N° de réf. du client

File No. - N° du dossier

CCC No./N° CCC - FMS No/ N° VME

Solicitation Amendment 007

This Amendment #007 is raised to incorporate Addendum 003. See attached Addendum 003.

All other terms and conditions remain unchanged.

The following changes in the tender documents are effective **immediately**. This Addendum will form part of the contract documents.

Amend/revise the Standard Contract Documents as follows:

Clarifications & General Information

1. Amendment #4 – Virtual Site Visit : mentions the possibility of and an alternate barge landing in Malsey Bay. This will not be ready for use at the time of construction and should not be considered as an option in bidding.

Questions

Question 8: a. With regards to the above project Drawing M0.02 shows the 30C domestic water connection and the 50mm forced sewer main connections at the top of the boardwalk whereas Detail 2 shows them being connected to existing connections at the bottom of the ramp. Which is correct?

Response: a. 1/M0.02 shows the landside pipe connections at the western properties, pipes running underside boardwalk to ramp. 2/M0.02 shows the pipes running down the ramp onto the float and connecting to the existing building piping halfway between the ramp and building.

Question 8 b. What fixture type is above the sink in the bathrooms?

Response: b. Type “J” fixture is to be mounted above the sinks/mirror in the washrooms (5 locations). Horizontal mounting in this location. Note: type “J” at desks to be mounted horizontally, centred between wall and window.

Question 9: a. Please confirm Security is only an empty conduit system as per General Notes 2 (drawing E1.00)

9 b. Does electrical need to provide the communication cable in the conduit system (Cat 5E) or is it only an empty conduit system and wired is by Owner?

Response: a. Correct, just conduit, box, and string.

b. Supply all required communications wiring , devices and rack as per electrical drawings (AES) and detail 7/E203.

Question 10: One of our subs is requesting that RA Bruce & Associates be added to the balancing/commissioning list.

Response: RA Bruce & Associates, 1339 Loseth Drive, Kelowna, BC is an acceptable Agency to offer Balancing and Commissioning Services as outlined in specification section 21 01 00 - 1.29.

End of Addendum