



## RETURN BIDS TO:

## RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution  
Public Works and Government Services Canada - Pacific  
Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> CCG SAR Crew Residence Construction CCG SAR Crew Residence Construction and Float Services	
<b>Solicitation No. - N° de l'invitation</b> F1700-204710/A	<b>Amendment No. - N° modif.</b> 007
<b>Client Reference No. - N° de référence du client</b> F1700-204710	<b>Date</b> 2021-04-15
<b>GETS Reference No. - N° de référence de SEAG</b> PW-SPWY-038-8931	
<b>File No. - N° de dossier</b> PWY-0-43162 (031)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> Pacific Daylight Saving Time PDT <b>on - le 2021-04-29</b> Heure Avancée du Pacifique HAP	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Costa (PWY), Michaela	<b>Buyer Id - Id de l'acheteur</b> pwy031
<b>Telephone No. - N° de téléphone</b> (236) 888-7800 ( )	<b>FAX No. - N° de FAX</b> ( ) -
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> DFO – Hartley Bay, BC	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation. - N° de l'off. à comm.  
F1700-204710/A

Amd. No. - N° de la modif.  
007

Buyer ID - Id de l'acheteur  
PWY031

Client Ref. No. - N° de réf. du client

File No. - N° du dossier

CCC No./N° CCC - FMS No/ N° VME

---

**Les documents français seront disponibles sur demande.**

### **Solicitation Amendment 007**

This Amendment #007 is raised to incorporate Addendum 003. See attached Addendum 003.

**All other terms and conditions remain unchanged.**

The following changes in the tender documents are effective **immediately**. This Addendum will form part of the contract documents.

**Amend/revise the Standard Contract Documents as follows:**

**Clarifications & General Information**

1. Amendment #4 – Virtual Site Visit : mentions the possibility of and an alternate barge landing in Malsey Bay. This will not be ready for use at the time of construction and should not be considered as an option in bidding.

**Questions**

**Question 8: a.** With regards to the above project Drawing M0.02 shows the 30C domestic water connection and the 50mm forced sewer main connections at the top of the boardwalk whereas Detail 2 shows them being connected to existing connections at the bottom of the ramp. Which is correct?

**Response: a.** 1/M0.02 shows the landside pipe connections at the western properties, pipes running underside boardwalk to ramp. 2/M0.02 shows the pipes running down the ramp onto the float and connecting to the existing building piping halfway between the ramp and building.

**Question 8 b.** What fixture type is above the sink in the bathrooms?

**Response: b.** Type “J” fixture is to be mounted above the sinks/mirror in the washrooms (5 locations). Horizontal mounting in this location. Note: type “J” at desks to be mounted horizontally, centred between wall and window.

**Question 9: a.** Please confirm Security is only an empty conduit system as per General Notes 2 (drawing E1.00)

**9 b.** Does electrical need to provide the communication cable in the conduit system (Cat 5E) or is it only an empty conduit system and wired is by Owner?

**Response: a.** Correct, just conduit, box, and string.

**b.** Supply all required communications wiring , devices and rack as per electrical drawings (AES) and detail 7/E203.

**Question 10:** One of our subs is requesting that RA Bruce & Associates be added to the balancing/commissioning list.

**Response:** RA Bruce & Associates, 1339 Loseth Drive, Kelowna, BC is an acceptable Agency to offer Balancing and Commissioning Services as outlined in specification section 21 01 00 - 1.29.

**End of Addendum**