



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet EGD East End Extension & Section 3	
Solicitation No. - N° de l'invitation EZ108-211059/A	Amendment No. - N° modif. 006
Client Reference No. - N° de référence du client	Date 2021-04-26
GETS Reference No. - N° de référence de SEAG PW-\$PWY-036-8938	
File No. - N° de dossier PWY-0-43153 (036)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Pacific Daylight Saving Time PDT on - le 2021-05-06 Heure Avancée du Pacifique HAP	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Martin (PWY), Delia	Buyer Id - Id de l'acheteur pwy036
Telephone No. - N° de téléphone (778) 707-2139 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: PWGSC – Esquimalt Graving Dock – Victoria, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EZ108-211059

Amd. No. - N° de la modif.
006

Buyer ID - Id de l'acheteur
PWY036

Client Ref. No. - N° de réf. du client
R.096320.002

File No. - N° du dossier

CCC No./N° CCC - FMS No./N° VME

This Amendment #006 is raised to:

- 1: Answer Bidder questions.
 - 2: Issue Addendum #4.
-

1: Bidder question:

Q1: With respect to the insurance requirements, we would ask the following be amended: "The Policy shall be endorsed to provide the Owner with not less than 30 day notice in writing in advance of any cancellation or change or amendment restricting coverage." The insurers are not able to provide notice of change or amendment restricting coverage, they will endeavor to provide notice of cancellation only.

A1: Insurance terms and conditions will remain as listed.

2: Issue Addendum #4.

Please see Addendum #4 attached.

All other terms and conditions remain unchanged.

Addendum 4: The following changes/clarifications in the tender documents are effective immediately. This addendum will form part of the contract documents.

Questions and Clarifications

Question 1:

Regarding Item 23 – Repair Type 5C, the quantity includes the stair tread repairs according to the specification. But the quantity seems not to include it in the unit price table. Could you confirm the quantity?

Answer 1:

Quantity listed for item 23 includes stair treads.

Question 2:

Is the existing east end wall reinforced? If yes, could you provide the rebar density (rebar weight vs concrete volume)?

Answer 2:

The existing East End wall is generally unreinforced mass concrete, however there may be occasional localized reinforcement. Refer to EGD General Plans 1925 drawings in Appendix F.

END OF ADDENDUM 4