



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Storm Water Drainage	
Solicitation No. - N° de l'invitation EZ899-212713/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client	Date 2021-05-04
GETS Reference No. - N° de référence de SEAG PW-\$PWY-028-8960	
File No. - N° de dossier PWY-1-44002 (028)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Pacific Daylight Saving Time PDT on - le 2021-05-18 Heure Avancée du Pacifique HAP	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lam (PWY), Tian	Buyer Id - Id de l'acheteur pwy028
Telephone No. - N° de téléphone (604) 363-7968 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: CSC - N & W Perimeter, Mission Institution - Mission, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EZ899-212713/A

Amd. No. - N° de la modif.
001

Buyer ID - Id de l'acheteur
pwy028

Client Ref. No. - N° de réf. du client

File No. - N° du dossier CCC No./N°

CCC - FMS No./N° VME

Les documents seront disponibles en français sur demande.

The Solicitation Amendment 001 is raised to issue Addendum 001.

Please see Addendum 001 herein.

All other terms and conditions remain unchanged.

THE FOLLOWING ADDENDUM SUPERCEDES INFORMATION CONTAINED IN DRAWINGS AND SPECIFICATIONS ISSUED FOR THE PROJECT TO THE EXTENT REFERENCED. THE FOLLOWING CHANGES IN THE TENDER DOCUMENTS ARE EFFECTIVE IMMEDIATELY. THIS ADDENDUM WILL FORM PART OF THE CONTRACT DOCUMENTS.

Question(s) and Answer(s) from Bidder(s)

Question 1 – *Can you please provide details on the required security measures for the contractor as well as subcontractors/delivery drivers.*

Answer 1- A security gate pass is required for all works and delivery drivers. Once the contract is awarded, gate pass requests to be submitted at least 1 week prior to work starting

Question 2 - 1.2.2.1 References a traffic management plan. Is the contractor allowed to close the road for the duration of the works as per 1.15.6, or will there be certain times where a flagger/traffic person will be required?

Answer 2 - No closure of the roadway is permitted, CSC will revise the road access for the Mobile Security checks once the contract is awarded.

Question 3 - Will all backfill/asphalt require compaction testing?

Answer 3 - As per section 01 45 00, points 1.3, 1.4, 1.5 contain answers to Question 3

Question 4 – Section 1.12 of the general instructions refers to the contractor obtaining and paying for any permits/certificates/licenses ... required

Answer 4 – None are required