



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Réception des soumissions - TPSGC / Bid Receiving -
PWGSC

Voir dans le document/

See herein

NA

Quebec

NA

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

TPSGC/PWGSC
1550 Avenue d'Estimauville
Québec
Québec
G1J 0C7

Title - Sujet Radoub M.L. Black été 2021	
Solicitation No. - N° de l'invitation F3065-210008/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client F3065-21-0008	Date 2021-05-19
GETS Reference No. - N° de référence de SEAG PW-\$QCV-018-18158	
File No. - N° de dossier QCV-1-44003 (018)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Eastern Daylight Saving Time EDT on - le 2021-06-08 Heure Avancée de l'Est HAE	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Piras, Gabriel	Buyer Id - Id de l'acheteur qcv018
Telephone No. - N° de téléphone (418) 956-2350 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

**TITLE : CCGS MARTHA L. BLACK - REFIT SUMMER 2021
AMENDMENT 003**

Included in the present Amendment:

1. Solicitation closing date extension
2. Questions and answers 1 to 14
3. Modifications to the Specifications
4. Addition of technical documents

SOLICITATION CLOSING DATE EXTENSION

Solicitation closing date is extended from June 1, 2021, to **June 8, 2021**.

QUESTIONS AND ANSWERS

Question 1

11.3 Laundry - Has a laundry arrangement plan been developed?

Answer: Yes. Drawing 11.3.c attached. Please also refer to 11.3.d General arrangement.

Question 2

11.3.C.10 - It is understood that the 3 washers and a sink will be GSM. Please confirm.

Answer: The 3 washer/dryer sets and one sink will be GSM

Question 3

11.3.C.11 - Do you have details on the new equipment?

Answer: Maytag MLE22PRAZW or similar.

Question 4

11.3.C.12 - Do you have details on the new counter and cabinets?

Answer: Yes. Please see attached drawing 11.3.c.

Question 5

11.3.C.28 – Could you provide details on the new receptacles? The wire lengths will be required for estimation.

Answer: Estimation of 5m per unit. Standard 4 wire receptacle for dryers outlet.

Question 6

11.4 Wipers - Can an electrical plan of existing controls be provided?

Answer: See attached drawing 11.4.c-80-50.

Question 7

11.4 Wipers - Is the power, voltage of the new wipers the same as for the existing ones?

Answer: Yes, power and voltage are identical. Make Wynn, series C _Model C2139B2CEACIA.

Question 8

11.4.C.13 - Details of the desired console location and console repair must be provided for evaluation.

Answer: The location of the controls is identical to what is currently in place. No console repairs are expected. The front panel of the controls will need to be installed on the console and this may require an extension of the cables between the front panel and the controller housing.

Question 9

11.5 Landing lights - 11.5.C.17 - Need current installation electrical plan, route of existing cables, control panel detail, junction box?

Answer: See attached drawing 11.5.b

Question 10

11.5 Landing lights - Need new light positioning plan.

Answer: Les six feux d'atterrissage avant devront être déplacés directement vers l'arrière et enlignés avec le couple 20. Voir dessin 11.5.c en p.j.

Question 11

11.5.C.8 - Need drawing of new landing lights, positioning plan.

Answer: The procurement process is currently underway.

Question 12

11.5.C.18 - Drawing of new tie-down points and positioning?

Answer: The two new tie-down points must be installed at frame -6 in line with the hangar track outboard edge port and starboard. See attached drawing 11.5.c.

Question 13

12.1 MKII Ground Detector - We need information to diagnose this system, manufacturer, service company, etc. Does CCG have a representative contact for this system?

Answer : Cette information n'est pas nécessaire pour la soumission et, pour des raisons d'équité envers les sous-traitants, nous ne pouvons pas fournir l'information.

Question 14

17.1 Speed Crane - No information on the electrical portion, just disconnect and reconnect motor. Will further modifications be required on the power and electrical control side with new 8T winch?

Answer: Disconnect and reconnect motor. No modification on electrical side.

MODIFICATIONS TO THE SPECIFICATIONS

The Technical Specifications are amended as follows.

DELETE paragraph 11.3.c.12.

INSERT the following paragraph :

"11.3.c.12 The Contractor must supply and install a support base for the GSM stainless steel counter top sink and storage assembly as illustrated in drawing 11.3.c. The support base must extend above the new concrete floor covering and secured by a minimum of 12 evenly spaced ½" (minimum) threaded rods welded to the deck."

Solicitation No. - N° de l'invitation
F3065-210008/A
Client Ref. No. - N° de réf. du client
F3065-210008

Amd. No. - N° de la modif.
003
File No. - N° du dossier
QCV-1-44003

Buyer ID - Id de l'acheteur
qcv018
CCC No./N° CCC - FMS No/ N° VME

ADDITION OF TECHNICAL DOCUMENTS

In answer to the Questions above, the following technical documents are included in this Amendment.

See electronic attachment « F3065-210008-A_Modif 003_pièces-jointes_Attachments.zip ».

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED