



RETURN BIDS TO /

**Parks Canada Agency, Bid Receiving Unit
National Contracting Services**

BID FAX : 1-877-558-2349

Bid Email:

pc.soumissionest-bidseast.pc@canada.ca

This is the only acceptable email address for responses to bid solicitation. Bids submitted by email directly to the Contracting Authority or to any other email address will not be accepted.

The maximum email file size is 15 megabytes. Parks Canada Agency (PCA) is not responsible for any transmission errors. Emails with links to bid documents will not be accepted.

INVITATION TO TENDER

Proposal to: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office :

Parks Canada Agency
National Contracting Services
Cornwall, Ontario, K6H 6S2

Title-Sujet Bank Stabilization on the Pic River - Pukaskwa National Park		
Solicitation No. - No. de l'invitation : 5P468-21-0004/A		Date : May 20, 2021
GETS Reference No. - No de reference de SEAG PW-21-00955774		Client Ref. No. - No. de réf du client. 791.15
Solicitation Closes (YY-MM-DD):		
at - à 2:00 PM	on - le 2021-05-27	Time Zone - Fuseau horaire : EDT - HAE
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: Adresser toute demande de renseignements à : Sheldon Lalonde (sheldon.lalonde@canada.ca)		
Telephone No. - No de téléphone: 343-585-3836		Fax No. - No de FAX: 1-877-558-2349
Destination of Goods, Services, and Construction: Destinations des biens, services et construction : See Herein - Voir aux présentes		

TO BE COMPLETED BY THE BIDDER (type or print)

À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)

Vendor/Firm Name - Nom du fournisseur/de l'entrepreneur	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de téléphone:	_____
Facsimile No. - N° de télécopieur:	_____
Signature	Date

INVITATION TO TENDER

AMENDMENT #2

THE PURPOSE OF THIS AMENDMENT IS TO GIVE EFFECT TO THE FOLLOWING CHANGE;

1. The closing date has changed to **Thursday, May 27, 2021 at 2:00pm EDT;**

2. Questions & answers #1:

1) To allow for meaningful engagement with affected First Nation and Métis groups we ask for a 2-week extension to the submission deadline. This will maximize the positive impact to the local communities by allowing greater collaboration with communities mentioned in the tender and properly forming IBPs that reflect local considerations with the needs of the of the project.

Answer: Due to rigid time window for works under water in order to minimize impacts to spawning fish, PCA is not able to extend the submission deadline requested.

2) Do you have any pictures of the riverbank area?

Answer: Please see the attached pictures of Riverbank area





- 3) Spec 01 35 43 Environmental procedures section 1.7 is "Vertical Double Silt Curtain". Is this silt curtain the same thing as the turbidity curtain? Does this mean we need to install 2 turbidity curtains in the river? The drawing only shows one line that is marked turbidity curtain.

Answer: Silt Curtain and Turbidity Curtain are the same thing. The specified Turbidity Curtain is all that is required in the water to isolate the work area. If they use the specified product they do not need to provide two layers.

- 4) For the item of transplant vegetation, can you please provide the number of trees and shrubs that we will be required to transplant

Answer: Approximately 130 saplings/live stakes will be provided to the contractor for planting within the project area. Remediation standard is ~ 5 woody plants/m square)"

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.