



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

**Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Paving Replacement & Misc. Works	
Solicitation No. - N° de l'invitation EZ899-212458/B	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client	Date 2021-05-27
GETS Reference No. - N° de référence de SEAG PW-\$PWY-036-8964	
File No. - N° de dossier PWY-0-43228 (036)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Pacific Daylight Saving Time PDT on - le 2021-06-01 Heure Avancée du Pacifique HAP	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Martin (PWY), Delia	Buyer Id - Id de l'acheteur pwy036
Telephone No. - N° de téléphone (778) 707-2139 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: PWGSC – km 325-355 & km 520-555 – Alaska Highway, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
EZ899-212458/B

Amd. No. - N° de la modif.
004

Buyer ID - Id de l'acheteur
PWY036

Client Ref. No. - N° de réf. du client
R.116050.001

File No. - N° du dossier
PWY-0-43228

CCC No./N° CCC - FMS No./N° VME

This Amendment #004 is raised to issue Addendum No. 004

Please see Addendum No. 004 attached.

The addendum will form part of the contract documents.

All other terms and conditions remain unchanged.

PUBLIC SERVICES AND PROCUREMENT CANADA

Professional and Technical Services, Real Property Services Branch, Pacific Region	
Alaska Hwy Km 325-355 & 520-555	Addendum 004
Paving and Miscellaneous Works	
Project No. R.116050.001	2021-05-26

The following changes in the tender documents are effective immediately. This addendum will form part of the Contract documents.

Questions from Bidders and Responses

Question 1: Purpose of the geotechnical investigation: The proposed slope inclinations appear to have been designed by Tetra Tech. Will the geotechnical drilling be for confirmatory of the soil conditions? If so, we can drill and perform routine lab testing on the soils, but no reporting cost will be required. Or does Tetra Tech require comments on the soil testing and require specialized testing (eg. Direct shear tests)? Or are the geotechnical boreholes for the installation of permanent monitoring instruments? If it is for monitoring instrument installations, what instruments are being proposed by the designer (eg. Slope inclinometers, vibrating wire piezometers etc.) and where are the proposed locations.

Response 1: As stated in Specification Section 31 24 14 – Excavation, Embankment, and Topsoil, the purpose of the geotechnical investigation is to determine whether the in-situ material achieves the definition for Embankment as provided in the Specifications. The installation of geotechnical monitoring instrumentation is not required.

Question 2: Proposed borehole plan: Does the owner have any proposed borehole plan/depth? Based on the cross sections, the change in elevation appears to be up to 15 m.

Response 2: The requirements of the test pits are listed in Specification Section 31 24 14 - Excavation, Embankment, and Topsoil (including updates in Addendum 004) and include:

- 1 Test Pit every 500 m² (or as directed by the Departmental Representative) evenly distributed within the limits of the Km 545 Embankment Borrow Source area.
- Test Pits shall be completed to a minimum depth of 5 m.
- Each test pit shall include collection of a representative samples to undertake five (5) moisture content tests and a sieve test/Atterberg limits test.

PUBLIC SERVICES AND PROCUREMENT CANADA

Professional and Technical Services, Real Property Services Branch, Pacific Region	Addendum 004
Alaska Hwy Km 325-355 & 520-555	
Paving and Miscellaneous Works	
Project No. R.116050.001	2021-05-26

Explanation of Addendum Presentation: Changes to the Specifications and Changes to the Contract Drawings sections of this Addendum have been presented as follows:

- *New text has been underlined for ease of identification.*
- *Removed text has a “strikethrough” and is to be deleted from the text.*

Changes to the Specifications:

1. Section 31 24 14 – Excavation, Embankment, and Topsoil

Delete:

- 1.4 – Submittals:

- 1.4.2.2 Results of the moisture content tests.

Insert:

- 1.4 – Submittals:

- 1.4.2.2 Results of the moisture content tests and sieve/Atterberg limits tests.

Delete:

- 2.1 – Embankment:

- 2.1.2.3 Each test pit shall include collection of a representative sample to undertake a moisture content test.

Insert:

- 2.1 – Embankment:

- 2.1.2.3 Each test pit shall include collection of a representative samples to undertake five (5) moisture content tests and a sieve test/Atterberg limits test.

Delete:

- 2.1 – Embankment:

- 2.1.4 If the geotechnical report finds that 50% or more of the borrow source material within 5 m of the existing surface achieves the definition of Embankment (as described in the 1.3 – Definitions in this Contract Specification) ~~and has a moisture~~

PUBLIC SERVICES AND PROCUREMENT CANADA

Professional and Technical Services, Real Property Services Branch, Pacific Region
Alaska Hwy Km 325-355 & 520-555 Addendum 004
Paving and Miscellaneous Works
Project No. R.116050.001 2021-05-26

~~content of 4.0% or less~~, then the Contractor shall sort and use all available material as a source of Embankment on the project.

Insert:

2.1 – Embankment:

2.1.4 If the geotechnical report finds that 50% or more of the borrow source material within 5 m of the existing surface achieves the definition of Embankment (as described in the 1.3 – Definitions in this Contract Specification) then the Contractor shall sort and use all available material as a source of Embankment on the project.