



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
See herein for bid submission
instructions/

Voir la présente pour les
instructions sur la présentation
d'une soumission

NA

NA

Revision to a Request for a Standing Offer

Révision à une demande d'offre à commandes

Regional Individual Standing Offer (RISO)

Offre à commandes individuelle régionale (OCIR)

The referenced document is hereby revised; unless
otherwise indicated, all other terms and conditions of
the Offer remain the same.

Ce document est par la présente révisé; sauf
indication contraire, les modalités de l'offre demeurent
les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Public Works and Government Services Canada -
Pacific Region
219 - 800 Burrard Street
800, rue Burrard, pièce 219
Vancouver, BC V6Z 0B9

Title - Sujet Fabrication of Infrastructure	
Solicitation No. - N° de l'invitation K3F31-210578/A	Date 2021-06-01
Client Reference No. - N° de référence du client K3F31-210578	Amendment No. - N° modif. 002
File No. - N° de dossier VAN-1-44001 (524)	CCC No./N° CCC - FMS No./N° VME
GETS Reference No. - N° de référence de SEAG PW-\$VAN-524-8959	
Date of Original Request for Standing Offer 2021-04-22 Date de la demande de l'offre à commandes originale	
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Pacific Daylight Saving Time PDT on - le 2021-06-14 Heure Avancée du Pacifique HAP	
Address Enquiries to: - Adresser toutes questions à: Yamamoto, Albert	Buyer Id - Id de l'acheteur van524
Telephone No. - N° de téléphone (604) 562-8773 ()	FAX No. - N° de FAX () -
Delivery Required - Livraison exigée	
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: Environment and Climate Change Canada See herein.	
Security - Sécurité This revision does not change the security requirements of the Offer. Cette révision ne change pas les besoins en matière de sécurité de la présente offre.	

Instructions: See Herein

Instructions: Voir aux présentes

Acknowledgement copy required Accusé de réception requis	Yes - Oui <input type="checkbox"/>	No - Non <input type="checkbox"/>
The Offeror hereby acknowledges this revision to its Offer. Le proposant constate, par la présente, cette révision à son offre.		
Signature	Date	
Name and title of person authorized to sign on behalf of offeror. (type or print) Nom et titre de la personne autorisée à signer au nom du proposant. (taper ou écrire en caractères d'imprimerie)		
For the Minister - Pour le Ministre		

Solicitation No. - N° de l'invitation
K3F31-210578/A
Client Ref. No. - N° de réf. du client
K3F31-210578

Amd. No. - N° de la modif.
002
File No. - N° du dossier
xxxxx.XXXXXX-XXXXXX

Buyer ID - Id de l'acheteur
VAN524
CCC No./N° CCC - FMS No./N° VME

1.2 Summary

Delete: The period of the standing offer will be three (3) years from the date of Standing Offer award.

Insert: The period of the standing offer will be **two (2)** years from the date of Standing Offer award.

6.4.1 Period of the Standing Offer

Delete: The period for making call-ups against the Standing Offer is from _____ to _____.
Three years

Insert: The period for making call-ups against the Standing Offer is from _____ to _____.
Two years

ANNEX "A"

STATEMENT OF WORK

BACKGROUND:

Delete: The period of the standing offer will be three (3) years from the date of Standing Offer award.

Insert: The period of the standing offer will be **two (2)** years from the date of Standing Offer award.

Solicitation No. - N° de l'invitation
K3F31-210578/A
Client Ref. No. - N° de réf. du client
K3F31-210578

Amd. No. - N° de la modif.
002
File No. - N° du dossier
xxxxx.XXXXXX-XXXXXX

Buyer ID - Id de l'acheteur
VAN524
CCC No./N° CCC - FMS No./N° VME

Questions (Q) and Answers (A):

Q1. For the pricing of a complete A-frame and platform. I see in the bill of materials and on the drawings that a 1m, 2m and 3m A-frame does not require a platform. Do I add the value of a platform to these?

A1. No. there is no platform for 1-3m A-frames.

Q2. For all the A-frame prices are you requiring the price of the ladders, ladder brackets, cages and HD gate to be added to the A-frame price? It only says A-frame and platform?

A2. Any A-frame that requires a ladder, ladder bracket, cage and platform – must include the price in the A-frame as follows:

HD A-frame size 2m and 3m – only ladder

HD A-frame 4m and larger – Ladders, ladder brackets, cages, and the HD gate.

Q3. Can we specify cost for each year (i.e. yr #1, #2, #3)? Would you accept this?

A3. No, this is not acceptable. All Bidders must bid the same way. Period of SO will be revised.

Q4. Assembly number 2812-R3 Crosby G400 eye nut is not currently available. Would you accept a substitute an appropriate turnbuckle and 1-1/4" rod?

A4. No, the eye nut must be 2812-R3 Crosby G400. If it is not currently available, we will wait until it is available.

Q5. Our galvanizing shop uses ASTM A123 code for their process which seems to be essentially the same as the CSA G164 code specified with a few extra restrictions and allows the use of recycled zinc. Hopefully this is an acceptable procedure to replace the CSA spec.

A5. Yes, as long as the proposed solution provides similar corrosion protection.