



# TENDER AMENDMENT #1

## RETURN BIDS TO:

### Email

DFOtenders-soumissionsMPO@dfo-mpo.gc.ca  
Cc : mazen.obeid@dfo-mpo.gc.ca

The referenced document is hereby amended: unless otherwise indicated, all other terms and conditions of the contract remain the same.

<b>Title :</b> Paint work, Levis radar tower		
<b>Solicitation No.:</b> 30000394	<b>Amendment No.:</b> 001	<b>Date:</b> June 9, 2021
<b>Client Reference No.</b> 30000394		
<b>Solicitation Closes:</b>		
<b>At:</b> 02:00 PM	<b>On:</b> June 14, 2021	<b>Time Zone:</b> EDT (Eastern Daylight Time)
<b>Address Inquiries to:</b>  Mazen Obeid		
<b>Telephone No:</b>  (613) 299-2564	<b>Email Address:</b>  mazen.obeid@dfo-mpo.gc.ca	
<b>TO BE COMPLETED BY THE BIDDER (type or print)</b>		
<hr/>		
<b>Vendor/Firm Name</b> <hr/>		
<b>Address</b> <hr/>		
<b>Name of person authorized to sign on behalf of the Vendor/Firm</b> <hr/>		
<b>Title</b> <hr/>		
<b>Signature</b> <hr/>		<b>Date</b> <hr/>



## AMENDMENT 001

This amendment is being raised to *respond to questions submitted in response to solicitation 30000394*.

### A. QUESTIONS AND ANSWERS

- Q1. Is it possible to visit the site?
- A1. Yes, it's possible to go visit the site at any time from the outside. The bidder will not be able to go inside and/or have access to the top of the tower, but the site is accessible at all times and they will be able to walk around the structure from the outside.
- Q2. The specifications document mentions the usage of MonoTop 623 to repair the damaged or cracked concrete surfaces. However, there is no mention of how much repairs are to be done. In order to have a fair bidding process, can you specify the quantity of repairs needed so it is taken into account while submitting a bid ?
- A2. Consider using MonoTop 623 for cracked surfaces of 5 linear meters.
- Q3. We have to redo the paint work on the entire tower. This has two outer ladders and two antennas. We would like to know if we are responsible for dismantling these items.
- A3. Ladders and antennas are anchored to the concrete, so they will not be removed during the work. The Contractor shall figure out a method to paint under the ladder and around the antennas.
- Q4. We would like to know who we should refer to in order to be able to dismantle the two antennas during our work. In the case that we are responsible for this dismantling, we need to know who to contact in order to be able to foresee the possible costs.
- A4. No dismantling will be planned or required. CCG technicians will make service interruptions when the Contractor is ready to paint the antennas and / or radar.

***All other terms and conditions remain the same.***