



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

Bid Receiving - PWGSC / Réception des soumissions -  
TPSGC

11 Laurier St./11 rue Laurier

Place du Portage, Phase III

Core 0B2 / Noyau 0B2

Gatineau, Québec K1A 0S5

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**

Raison sociale et adresse du  
fournisseur/de l'entrepreneur

**Issuing Office - Bureau de distribution**

Construction Services Division/Division des services de  
construction

140 O'Connor Street

140, rue O'Connor

Ontario

Ottawa

K1A 0S5

<b>Title - Sujet</b> Hangar 11 Flat Roof Replacement Hangar 11 Flat Roof Replacement	
<b>Solicitation No. - N° de l'invitation</b> EP916-212401/A	<b>Amendment No. - N° modif.</b> 002
<b>Client Reference No. - N° de référence du client</b> 20212401	<b>Date</b> 2021-06-09
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$\$\$FG-362-80079	
<b>File No. - N° de dossier</b> fg362.EP916-212401	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> Eastern Daylight Saving Time EDT <b>on - le 2021-06-22</b> Heure Avancée de l'Est HAE	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Kelly, Jessica	<b>Buyer Id - Id de l'acheteur</b> fg362
<b>Telephone No. - N° de téléphone</b> (873) - ( )	<b>FAX No. - N° de FAX</b> ( ) -
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

**The following changes to the tender documents are effective immediately. This amendment will form part of the contract documents.**

Amendment 002 is issued for the following:

- (1) Bidder Question and Response; and
  - (2) Issue Addendum 01
- 

**(1) Bidder Question and Response**

**QUESTION # 1:**

There are no specifications on any of the slope insulation. Is the roof deck structurally sloped? And is the slope insulation 1%, 2%, or even 4%?

**REVISED ANSWER # 1:**

Bid in accordance with the Specifications, Section 07 52 00: 2.5.1.1 - 2.5.1.3 and refer to Addendum 01.

---

**QUESTION # 2:**

Would be possible to get pictures of the roof since there is not site visit planned?

**ANSWER # 2:**

Please bid in accordance with the Specifications and Drawings.

---

**ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME**

Solicitation No. - N° de l'invitation  
EP916-212401

Amd. No. - N° de la modif.  
002

Buyer ID - Id de l'acheteur  
FG 362

Client Ref. No. - N° de réf. du client  
20212401

File No. - N° du dossier  
EP916-212401

CCC No./N° CCC - FMS No./N° VME  
R.064512.069

---

## **ADDENDUM 01**

## Addendum 1

date: Ottawa, June 8, 2021  
Addendum Number: 1  
Project Number: R.064512.069

---

The following changes in the Bid Documents are effective immediately.  
This addendum is to form part of the Construction Documents.

### DRAWINGS:

- 1 A200 Architecture
  - .1 Detail 1: Roof Plan

### SPECIFICATIONS:

1Section 07 52 00 – Modified Bituminous Membrane Roofing

- .1 Refer to paragraph 2.5 Insulation:

Delete the following:

"Polyisocyanurate Insulation: Closed-cell polyisocyanurate foam insulation board laminated on both sides with a fiberglass yarn-reinforced organic paper.

- .1 North roof: Two layers 38.1 mm each for total 76.2 mm.
- .2 South upper roof: Two layers 38.1 mm each for total 76.2 mm.
- .3 South lower Roof: two layers 50 mm each for total 100 mm."

Replace with the following:

"Polyisocyanurate Insulation: Closed-cell, non-sloped polyisocyanurate foam insulation board laminated on both sides with a fiberglass yarn-reinforced organic paper.

- .1 North roof: Two layers 38.1 mm each for total 76.2 mm.
- .2 South upper roof: Two layers 38.1 mm each for total 76.2 mm.
- .3 South lower Roof: two layers 50 mm each for total 100 mm."

- .2 Refer to paragraph 2.5 Insulation, Article (3)

Delete the following:

"Provide crickets on the upslope side of all mechanical equipment and between in-line drains."

Replace with the following article:

"Provide 2% sloped insulation to create crickets on the upslope side of all mechanical equipment and between in-line drains."

---