

The following changes to the tender documents are effective immediately and will form part of the contract documents:

Questions from Contractors:

1. **Q:** What is the existing Fire Alarm system?

A: The existing fire alarm system is a Siemens Cerberus Pyrotronics system. Refer to keynote 1 on Sheet E001 and Specifications Section 28 31 00 article 2.2.

2. **Q:** Is the proposed Sound Masking connected to other floors or local to the 3rd floor?

A: The proposed sound masking system is to be local to the tenant area only on the 3rd floor.

END OF ADDENDUM NO. 2