



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving - PWGSC / Réception des soumissions -
TPSGC

11 Laurier St./11 rue Laurier

Place du Portage, Phase III

Core 0B2 / Noyau 0B2

Gatineau, Québec K1A 0S5

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Construction Services Division/Division des services de
construction

140 O'Connor Street

140, rue O'Connor

Ontario

Ottawa

K1A 0S5

Title - Sujet Fuel Storage Tank Removal Fuel Storage Tank Removal	
Solicitation No. - N° de l'invitation EP916-212422/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client 20212422	Date 2021-06-16
GETS Reference No. - N° de référence de SEAG PW-\$\$\$FG-374-80077	
File No. - N° de dossier fg374.EP916-212422	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Eastern Daylight Saving Time EDT on - le 2021-06-29 Heure Avancée de l'Est HAE	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Vani-Machado, Alba	Buyer Id - Id de l'acheteur fg374
Telephone No. - N° de téléphone (873) 355-4048 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

The following changes to the tender documents are effective immediately. This amendment will form part of the contract documents.

Amendment 003 is issued for the following:

(1) Bidders' Question and Response;

(1) Bidder Question & Answer

QUESTION # 1:

Could you please clarify whether there's a Fuel Management System (FMS) component required for this bulk fuel storage tank removal & replacement?

FMS defined as, proprietary technology to track, record and manage fuel dispensing by Operator, Vehicle, Odometer, Fuel Type, Litres Dispensed, etc.

ANSWER # 1: Bidders are to refer to the design documents.

QUESTION # 02:

With reference to the tender in objet, is it possible to have some photos of the installation to be dismantled, mainly:

- Underground tank,
- Above ground tank,
- Wall penetration,
- Interior works area

ANSWER # 02: There will be no pictures for security reasons.

QUESTION # 03:

It is specified that we have to provide diesel for 12 hours of generator operation. Could you please indicate the diesel consumption per hour of the existing generator?

ANSWER # 03: 100 L/hr

QUESTION # 04:

With reference to the Survey report on designated substance and hazardous building, some points are not perfectly clear.


Could you please confirm that all pipes to be dismantled are not insulated with asbestos?

Also could you please confirm that the existing wall penetration are to be reused? If not, does the wall where new penetration are to be created contain asbestos or any other designated substance?

ANSWER # 04: Please refer to the designated substance survey. The fuel piping does not have any insulation but may contain lead paint. The existing wall penetration is not to be reused. The new penetration area may contain asbestos and lead paint.

QUESTION # 05:

On drawing E01, the New Construction Note #5 is not pointing at anything specific. Can you specify where they are referring to?



ANSWER # 05: The notes are pointing to the new fuel tank and new bollards. They are shown on a light layer on the electrical drawing as they are both installed by other trades (under this contract).

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME

Solicitation No. - N° de l'invitation
EP916-212422

Amd. No. - N° de la modif.
003

Buyer ID - Id de l'acheteur
FG 374

Client Ref. No. - N° de réf. du client

File No. - N° du dossier
FG374 EP916-212422

CCC No./N° CCC - FMS No./N° VME
