

Public Works and Government Services Canada	Winnipeg, Manitoba Global Affairs Canada (GAC) Regional Office Fit-Up	Addendum No. 4 Page 1 of 2
Project No.: R.104185		June 17, 2021

The following changes to the tender documents are effective immediately and will form part of the contract documents:

ARCHITECTURAL

4.1 GENERAL

- 4.1.1 The building permit has already been applied for and the cost of it has been paid for by the Prime Consultant. The permit will be transferred to the successful contractor after award.
- 4.1.2 The dimension of the passenger elevator is 1828mm L (72") x 1562mm (61.5") W x 2209mm (87") H.

4.2 RESPONSE TO INQUIRIES DURING TENDER PERIOD

- 4.2.1 Question: "09 22 16 – 2.1.1 shows 0.53 mm thickness or 16 gauge steel studs for all walls. Is this a misprint?"
Answer: There is no reference to 16ga steel studs in Section 09 22 16, only 16ga Channels under Rigid Structural Support.
- 4.2.2 Question: "09 21 99 – 3.3 lists section 05 50 00 as suppling the security mesh. Just to clarify the mesh is supplied to us by others and we install? If it is supplied by others will it be brought to the 3rd floor by them?"
Answer: Co-ordination of sub-trades is the responsibility of the General Contractor.
- 4.2.3 Question: "09 51 13 - 2.1.1.4 Warning labels printed on sound baffle. Are the labels in our scope?"
Answer: This will be for the General Contractor to co-ordinate.
- 4.2.3 Question: "Are HMF frames 301 & 302 in pieces or will they fit into the elevator?"
Answer: This will be for the General Contractor to co-ordinate.

4.3 SPECIFICATIONS

- 4.3.1 Section 08 11 00 – Metal Doors & Frames
Paragraph 2.7.7 – Fabrication – Doors – Omit:
~~.7 – Sound Rated Door after Fabrication: STC of minimum 48, measured to ASTM E413.~~
- 4.3.2 Section 08 14 16 – Flush Wood Doors & Metal Frames
Paragraph 2.1.4 – Non-Rated Wood Flush Doors – Omit:
~~.4 – STC Rating: As specified and scheduled.~~
- 4.3.3 Section 09 51 99 – Acoustical Ceilings for Minor Work
Paragraph 2.1.2.10 – Materials – Omit:
~~.10 – Face Plate: Armstrong, Axiom unslotted face plate (AXTBC), 152mm wide, white~~

Public Works and Government Services Canada	Winnipeg, Manitoba Global Affairs Canada (GAC) Regional Office Fit-Up	Addendum No. 4 Page 2 of 2
Project No.: R.104185		June 17, 2021

4.4 CLARIFICATION

4.4.1 No STC rated doors are required within the project scope.

4.4.2 The STC requirements outlined in the Interior Wall Types on A01 refer to the overall assembly of the partition and not any one component.

MECHANICAL

4.5 SPECIFICATIONS

4.5.1 Section 01 91 13 - General Commissioning (CX) Requirements and Section 01 91 13.13 - Commissioning Plan:

- .1 A 3rd party Commissioning Agent is not required. Contractor can appoint someone within their company as their Commissioning Agent.

END OF ADDENDUM NO. 4