

Solicitation No. - N° de l'invitation
EQ734-220069/A

Amd. No. - N° de la modif.
001

Buyer ID - Id de l'acheteur
PWL003

Client Ref. No. - N° de réf. du client
R.106283.001

File No. - N° du dossier
PWL-1-44014

CCC No./N° CCC - FMS No./N° VME

Questions and Answers:

Q: Are there any load restrictions for the site for storing or loading equipment and materials?

A: The existing dock is in a state of disrepair and has no rated capacity.

Q: Can you please confirm if the same concrete mix provided in 03 30 00 is required to be used for the pipe pile fill and the mass concrete for the water gauge well?

A: The same concrete mix as specified in 03-30-00 should be assumed for the pipe pile fill and the mass concrete for the water gauge well.

Q: As per estimate in tender the Quantity of 75mm to 150mm Crushed Rock is 1000 tonne and our estimate is 2800+ Tonne. As there is a lot of variation in the both the quantities I would like to confirm the quantity so that we can bid accordingly to create a win-win situation. Please enlighten us if there is any change into the quantity or if you need more information and feel free to reach out to us at any time.

A: Please adjust the bid form quantities as follows:

75mm to 150mm Crushed Rock = 2000 tonnes

100 kg to 200 kg Crushed Rock = 2000 tonnes

See Revised Unit Price Table.

Q: SI15 requires the bidder to hold a valid security clearance as indicated in SC01. SC01 then references Annex A, which says to "See Buyandsell.gc.ca attachment". However none of the attachments appear to reference security requirements. Can you please confirm the following:

- a. What type/level of security clearance is required to bid the job?
- b. Will individuals require security clearance to attend the site visit?

A: Security will be required during construction. DFO will provide an escort for the contractor per the attestation form.

Delete:

SI15 - INDUSTRIAL SECURITY RELATED REQUIREMENTS;

SC01 - INDUSTRIAL SECURITY RELATED REQUIREMENTS, DOCUMENTS
SAFEGUARDING and

ANNEX A - SECURITY REQUIREMENT CHECK LIST (SRCL), in its entirety