



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Bldg M2A CER Cooling Upgrade	
Solicitation No. - N° de l'invitation EZ899-220049/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client	Date 2021-06-24
GETS Reference No. - N° de référence de SEAG PW-\$PWY-036-9004	
File No. - N° de dossier PWY-1-44018 (036)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Pacific Daylight Saving Time PDT on - le 2021-06-29 Heure Avancée du Pacifique HAP	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Martin (PWY), Delia	Buyer Id - Id de l'acheteur pwy036
Telephone No. - N° de téléphone (778) 707-2139 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: CSC – Bldg M2A, Matsqui Institution – Abbotsford, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Amendment #001 is raised to address bidder questions.

Q1: New panel EB to be fed from CDP M2A. It appears that there is no room in this existing board. There is 1 vacant spot for a 3 pole breaker, but it is for a bigger frame breaker than a 150a. Please advise?

A1: We are investigating and will provide instruction soon.

Q2: Panel EB schedule calls for a 120v/15a cct for Heat Trace. I do not see anything on any drawings for this? If it is there, who supplies it and where is it?

A2: The heat trace is for condensate line from indoor to outdoor unit. Heat trace is needed and Raychem will provide heat trace. Electrical contractor to provide power connection.

Q3: E101 & E200 state that the scale is 1:50 on 8 ½ x 11. Just making sure this is correct?

A3: Drawing E101 and E200 are scaled 1:50 on a 24x36 sheet.

Q4: Drawing E101 detail 2 shows location of new fixtures. There is a junction box interfering with the location of the last fixture on the row. Can this be revisited to see if there is enough room to move the fixture over to the edge of the junction box and still have room for the diffuser. Can the diffuser move 3-4" away from the fixture? See attached drawing.

A4: Locations of light fixtures and junction boxes can be adjusted at site to make space. Contractor to coordinate at site and send suggested layout to elec / mech engineers for review.

Q5: The one line indicates that the new feed for the new panel EB come from CDP-M2a- however, on inspection on site, there is no room to install an new breaker in this location?

A5: We are investigating and will provide instruction soon.

Q6: On site it was indicated that the server can not be shut down, however in order to install the new breaker, conductors in the CDP, a shut down of the panel CDP will need to be done. Can you confirm when the shutdown is able to occur and how long the UPS will last on the shutdown.

A6: Please coordinate with Public Works and CSC for when shutdown can be scheduled.

Solicitation. - N° de l'off. à comm.
EZ899-220049/A

Amd. No. - N° de la modif.
001

Buyer ID - Id de l'acheteur
pwy036

Client Ref. No. - N° de réf. du client

File No. - N° du dossier
PWY-1-44018

CCC No./N° CCC - FMS No/ N° VME

Q7: Can the list of attendees to the site visit and on line information session be posted?

A7: Virtual site visit attendees:

Ainsworth Inc.

JF Butler & Sons

Port Of Spain Holdings Inc

Status Electrical

Marine Roofing

Entity Mechanical Ltd.

Site visit attendees:

Marine Roofing

JF Butler & Sons

Ainsworth Inc.

Status Electrical

All other terms and conditions remain unchanged.