

Part 1 General**1.1 REFERENCE STANDARDS**

- .1 American Society of Mechanical Engineers (ASME) (Latest edition)
 - .1 ASME B16.1, Cast Iron Pipe Flanges and Flanged Fittings.
- .2 ASTM International Inc. (Latest edition)
 - .1 ASTM A49, Standard Specification for Heat-Treated Carbon Steel Joint Bars.
 - .2 ASTM A126, Standard Specification for Grey Iron Castings for Valves, Flanges, and Pipe Fittings.
 - .3 ASTM A536, Standard Specification for Ductile Iron Castings.
 - .4 ASTM B61, Standard Specification for Steam or Valve Bronze Castings.
 - .5 ASTM B62, Standard Specification for Composition Bronze or Ounce Metal Castings.
 - .6 ASTM B85/B85M, Standard Specification for Aluminum-Alloy Die Castings.
 - .7 ASTM B209, Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate.
- .3 Manufacturers Standardization Society of the Valve and Fittings Industry, Inc. (MSS)
 - .1 MSS SP-61, Pressure Testing of Steel Valves.
 - .2 MSS SP-70, Grey Iron Gate Valves, Flanged and Threaded Ends.
 - .3 MSS SP-71, Grey Iron Swing Check Valves, Flanged and Threaded Ends.
 - .4 MSS SP-82, Valve Pressure Testing Methods.
 - .5 MSS SP-85, Cast Iron Globe and Angle Valves, Flanged and Threaded Ends.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00- Submittal Procedures.
- .2 Product Data:
 - .1 Provide manufacturer's printed product literature, specifications and datasheets for valves and include product characteristics, performance criteria, physical size, finish and limitations.

1.3 CLOSEOUT SUBMITTALS

- .1 Submit maintenance data for incorporation into manual specified in Section 01 78 00- Closeout Submittals.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00- Common Product Requirements with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements:

- .1 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
- .3 Packaging Waste Management: remove for reuse and return by manufacturer of crates padding packaging materials pallets in accordance with Section 01 00 10 – General Instructions.

1.5 MAINTENANCE MATERIAL SUBMITTALS

- .1 Extra Materials/Spare Parts:
- .2 Furnish following spare parts:
 - .1 Valve seats: one for every 10 valves each size, minimum 1.
 - .2 Discs: one for every 10 valves, each size, minimum 1.
 - .3 Stem packing: one for every 10 valves, each size, minimum 1.
 - .4 Valve handles: 2 of each size.
 - .5 Gaskets for flanges: one for every 10 flanged joints.
- .3 Tools:
 - .1 Furnish special tools for maintenance of systems and equipment.
 - .2 Include following:
 - .1 Lubricant gun for expansion joints.

Part 2 Products

2.1 MATERIAL

- .1 Valves:
 - .1 Except for specialty valves, to be of single manufacturer.
- .2 Standard specifications:
 - .1 Gate valves: MSS SP-70.
 - .2 Globe valves: MSS SP-85.
 - .3 Check valves: MSS SP-71.
- .3 Requirements common to valves, unless specified otherwise:
 - .1 Body, bonnet: ductile iron to ASTM A536 Grade 65-45-12.
 - .2 Connections: grooved end to ANSI B16.1.
 - .3 Inspection and pressure testing: to MSS SP-82.
 - .4 Bonnet gasket: non-asbestos.
 - .5 Stem: to have precision-machined Acme or 60 degrees V threads, top screwed for handwheel nut.
 - .6 Stuffing box: non-galling two-piece ball-jointed packing gland, gland bolts and nuts.
 - .7 Gland packing: non-asbestos.

- .8 Handwheel: die-cast aluminum alloy to ASTM B85/B85M or malleable iron to ASTM A49. Nut of bronze to ASTM B62.
- .9 Identification tag: with catalogue number, size, other pertinent data.
- .4 All products to have CRN registration numbers.

2.2 GATE VALVES

- .1 NPS 2 1/2 - 8, non rising stem, inside screw, iron trim, solid wedge disc:
 - .1 Body and multiple-bolted bonnet: with bosses in body and bonnet for taps and drains, full length disc guides designed to ensure correct re-assembly, Class 125.
 - .2 Disc: solid offset taper wedge, bronze to ASTM B62.
 - .3 Seat rings: renewable bronze to ASTM B62, screwed into body.
 - .4 Stem: bronze to ASTM B62.
 - .5 Disc: solid offset taper wedge, cast iron to ASTM A126 Class B, secured to wrought steel stem.
 - .6 Seat: integral with body.
 - .7 Stem: wrought steel.
 - .8 Operator: manual gear
 - .9 Bypass: complete with union and NPS globe valve as Section 23 05 23.01- Valves - Bronze,

2.3 GLOBE VALVES

- .1 NPS 2 1/2 - 10, OSY:
 - .1 Body: with multiple-bolted bonnet.
 - .2 WP: 860 kPa steam, 1.4 MPa CWP.
 - .3 Bonnet-yoke gasket: non-asbestos.
 - .4 Disc: bronze to ASTM B62, fully guided from bottom, securely yet freely connected to stem for swivel action and accurate engagement with disc.
 - .5 Seat ring: renewable, regrindable, screwed into body.
 - .6 Stem: bronze to ASTM B62.
 - .7 Operator: manual gear
 - .8 Bypass: complete with union and NPS globe valve as Section 23 05 23.01- Valves - Bronze,

2.4 VALVE OPERATORS

- .1 Install valve operators as follows:
 - .1 Handwheel: on valves except as specified.
 - .2 Handwheel with chain operators: on valves installed more than 2400 mm above floor in boiler rooms

Part 3 Execution**3.1 INSTALLATION**

- .1 Install rising stem valves in upright position with stem above horizontal.

3.2 CLEANING

- .1 Clean in accordance with Section 01 74 11- Cleaning.
- .2 Clean installed products in accordance to manufacturer's recommendation.
- .3 Waste Management: separate waste materials for reuse recycling in accordance with Section 01 00 10 – General Instructions.

END OF SECTION