

1.1 REFERENCE STANDARDS

- .1 American National Standards Institute/American Water Works Association (ANSI/AWWA) (Latest edition)
 - .1 ANSI/AWWA C111/A21.11, Standard for Rubber-Gasket Joints for Ductile-Iron Pressure Pipe and Fittings.
- .2 American Society of Mechanical Engineers (ASME) (Latest edition)
 - .1 ASME B16.1, Grey Iron Pipe Flanges and Flanged Fittings: Classes 25, 125, and 250.
 - .2 ASME B16.3, Malleable Iron Threaded Fittings: Classes 150 and 300.
 - .3 ASME B16.5, Pipe Flanges and Flanged Fittings: NPS ½ through NPS 24 Metric/Inch Standard.
 - .4 ASME B16.9, Factory-Made Wrought Buttwelding Fittings.
 - .5 ASME B18.2.1, Square Hex, Heavy Hex and Askew Head Bolts and Hex, Heavy Hex, Hex Flange. Loded Head and Lag Screws (Inch Series).
 - .6 ASME B18.2.2, Nuts for General Applications: Machine Screw Nuts, Hex, Square, Hex Flange, and Coupling Nuts (Inch Series).
- .3 ASTM International(Latest edition)
 - .1 ASTM A47/A47M, Standard Specification for Ferritic Malleable Iron Castings.
 - .2 ASTM A53/A53M, Standard Specification for Pipe, Steel, Black and Hot-Dipped, Zinc Coated Welded and Seamless.
 - .3 ASTM A536, Standard Specification for Ductile Iron Castings.
 - .4 ASTM B61, Standard Specification for Steam or Valve Bronze Castings.
 - .5 ASTM B62, Standard Specification for Composition Bronze or Ounce Metal Castings.
 - .6 ASTM E202, Standard Test Method for Analysis of Ethylene Glycols and Propylene Glycols.
- .4 CSA International(Latest edition)
 - .1 CSA B242, Groove and Shoulder Type Mechanical Pipe Couplings.
 - .2 CSA W48, Filler Metals and Allied Materials for Metal Arc Welding.
- .5 Manufacturer's Standardization of the Valve and Fittings Industry (MSS) (Latest edition)
 - .1 MSS-SP-67, Butterfly Valves.
 - .2 MSS-SP-70, Grey Iron Gate Valves, Flanged and Threaded Ends.
 - .3 MSS-SP-71, Grey Iron Swing Check Valves Flanged and Threaded Ends.
 - .4 MSS-SP-80, Bronze Gate, Globe, Angle and Check Valves.
 - .5 MSS-SP-85, Grey Iron Globe and Angle Valves, Flanged and Threaded Ends.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00- Submittal Procedures.
- .2 Product Data:

- .1 Submit manufacturer's instructions, printed product literature and data sheets for hydronic systems and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Shop Drawings:
 - .1 Indicate on drawings:
 - .1 Components and accessories.
- .1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.

1.3 CLOSEOUT SUBMITTALS

- .1 Submit in accordance with Section 01 78 00- Closeout Submittals.
- .2 Operation and Maintenance Data: submit operation and maintenance data for hydronic systems for incorporation into manual.
 - .1 Include special servicing requirements.

1.4 EXTRA STOCK MATERIALS

- .1 Supply spare parts as follows:
 - .1 Valve seats: 1 minimum for every ten valves, each size. Minimum one.
 - .2 Discs: 1 minimum for every ten valves, each size. Minimum one.
 - .3 Stem packing: 1 minimum for every ten valves, each size. Minimum one.
 - .4 Valve handles: 2 minimum of each size.
 - .5 Gaskets for flanges: 1 minimum for every ten flanges.

1.5 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section with manufacturer's written instructions 01 61 00- Common Product Requirements.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
 - .1 Store materials indoors and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect hydronic systems from nicks, scratches, and blemishes.
 - .3 Replace defective or damaged materials with new.
- .4 Develop Construction Waste Management Plan Waste Reduction Workplan related to Work of this Section.
- .5 Packaging Waste Management: remove for reuse by manufacturer and return of packaging materials padding, pallets, crates, as specified in 01 00 10 – General Instructions.

Part 2 Products**2.1 STEAM AND CONDENSATE LINE**

- .1 Piping: to ASTM A53/A53M, Grade B.
 - .1 Steam and Feed water:
 - .1 NPS 1/2 to 1-1/2: Sch. 80-ERW or seamless, plain ends.
 - .2 NPS 2 to 12 and over: Sch. 40-ERW or seamless, bevel ends.
 - .2 Condensate and soft water makeup: Sch. 80-ERW or seamless, plain or bevel ends.
- .2 Fittings for steam and feed water:
 - .1 NPS 1/2 to 1-1/2: Class 3000, 20 MPa, forged steel, socket weld, to ASTM A181/A181M, Class 70.
 - .2 NPS 2 to 10: Sch. 40, seamless, bevel ends, to ASTM A234/A234M, Grade WPB.
- .3 Fittings for condensate and soft water makeup:
 - .1 Sch. 80, seamless or ERW, plain ends, to ASTM A53/A53M, Grade B.
- .4 Couplings:
 - .1 NPS 1/2 to 1-1/2: Class 3000, 20 MPa, socket weld, to ASTM A181/A181M, Class 70.
- .5 Caps and plugs for drains:
 - .1 NPS 1/2 to 3/4: Class 3000, 20 MPa, to ASTM A181/A181M, Class 70.
- .6 Nipples for drains, vents, pressure gauges:
 - .1 NPS 1/2 to 3/4: Sch. 160, plain ends, to ASTM A106/A106M, Grade A.
- .7 All other nipples:
 - .1 NPS 1/2 to 1-1/2: Sch. 80, plain ends, to ASTM A106/A106M, Grade A.
- .8 Swage nipples:
 - .1 Sch. 80, seamless, to ASTM A106/A106M, Grade A.
- .9 Welding outlets:
 - .1 Sch. 160, bevel ends, to ASTM A181/A181M, Class 70.
- .10 Elbow welding outlets:
 - .1 Sch. 160, bevel ends, to ASTM A181/A181M, Class 70.
- .11 Unions:
 - .1 NPS 1/2 to 1-1/2: Class 3000, 20 MPa, screwed socket weld ends, forged steel, steel-to-steel ground seats, to ASTM A181/A181M, Class 70.
- .12 Flanges:
 - .1 NPS 1/2 and 3/4: Class 150, 1 MPa, raised face, socket weld or weld neck bored to match pipe, to ASTM A181/A181M, Class 70.

- .2 NPS 1 to 1-1/2: Class 150, 1 MPa, raised face, weld neck, bored to match pipe, to ASTM A181/A181M, Class 70.
- .3 NPS 2 to 12: Class 150, 1 MPa, raised face, weld neck, bored to match pipe, to ASTM A181/A181M, Class 70.
- .13 Orifice flanges:
 - .1 Class 300, 2 MPa, raised face, slip-on, bored to match pipe, to ASTM A181/A181M, Class 70.
- .14 Bolts and nuts:
 - .1 Alloy steel stud bolts to ASTM A193/A193M, Grade B7, with semi-finished hex head nuts, to ASTM A194/A194M, Grade 2H.
- .15 Gaskets:
 - .1 EDPM Fluoroelastomer, 1.6 mm thick, full face, rated for temperature and pressure of system.
- .16 Gate valves:
 - .1 NPS 1/2 to 1-1/2: Class 600, 4 MPa at 485 degrees C, forged steel body, socket weld, forged steel bolted bonnet and yoke, two-piece self-aligning forged steel gland-flange with stainless steel bolts, stainless steel gland, deep stuffing box, fully guided solid stainless steel wedge disc, renewable Stellite seats. Rising stem.
 - .2 NPS 2 to 12 and over: Class 300, 2 MPa, raised face flanged ends, cast steel body, OS&Y, flexible disc to ASTM A216/A216M, grade WCB.
- .17 Globe valves:
 - .1 NPS 1/2 to 3: Class 600, 4 MPa, forged steel body, one piece forged steel bolted bonnet and yoke, stainless steel stem and disc, stainless steel replaceable seat, socket weld ends, OS&Y.
- .18 Valves in external bypass around valves NPS 8 and larger:
 - .1 NPS 1 gate as specified above.
- .19 Check valves:
 - .1 NPS 1/2 to 1-1/2: Class 800, 5.5 MPa, forged steel body, horizontal lift check, socket weld, straight pattern body.
- .20 Drain valves:
 - .1 Gate valves, NPS 3/4 to 1-1/4, as specified above.
- .21 Strainers:
 - .1 NPS 1/2 to 2: Class 600, 4 MPa, socket weld, cast carbon steel body to ASTM A216/A216M, Grade WCB, Y pattern with 20 x 20 mesh Type 304 stainless steel screen, steel cap to ASTM A108, Grade 117.

Part 3 Execution

3.1 EXAMINATION

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for hydronic systems installation in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate in presence of Departmental Representative
 - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
 - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.

3.2 PIPING INSTALLATION

- .1 Install pipework in accordance with Section 23 05 05- Installation of Pipe Work.

3.3 CIRCUIT BALANCING VALVES

- .1 Install flow measuring stations and flow balancing valves as indicated.
- .2 Remove handwheel after installation and when TAB is complete.

3.4 CLEANING, FLUSHING AND START-UP

- .1 In accordance with Section 23 08 02- Cleaning and Start-Up of Mechanical Piping Systems.

3.5 TESTING

- .1 Test system in accordance with Section 21 05 01- Common Work Results for Mechanical.

3.6 BALANCING

- .1 Balance water systems to within plus or minus 5% of design output.

3.7 PERFORMANCE VERIFICATION

- .1 In accordance with Section 23 08 01- Performance Verification Mechanical Piping Systems.

3.8 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11- Cleaning.
 - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11- Cleaning.
- .3 Waste Management: separate waste materials for reuse recycling in accordance with Section 01 00 10 – General Instructions.
 - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

3.9

PROTECTION

- .1 Protect installed products and components from damage during construction.
- .2 Repair damage to adjacent materials caused by hydronic systems installation.

END OF SECTION