

**Part 1 General****1.1 REFERENCE STANDARDS**

- .1 American Society of Mechanical Engineers (ASME) (Latest edition)
  - .1 ASME B31.1, Power Piping.
- .2 ASTM International(Latest edition)
  - .1 ASTM A125, Standard Specification for Steel Springs, Helical, Heat-Treated.
  - .2 ASTM A307-07b, Standard Specification for Carbon Steel Bolts and Studs, 60,000 PSI Tensile Strength.
  - .3 ASTM A563-07a, Standard Specification for Carbon and Alloy Steel Nuts.
- .3 Factory Mutual (FM)
- .4 Manufacturer's Standardization Society of the Valves and Fittings Industry (MSS) (Latest edition)
  - .1 MSS SP58, Pipe Hangers and Supports - Materials, Design and Manufacture.
  - .2 MSS SP69, Pipe Hangers and Supports - Selection and Application.
  - .3 MSS SP89, Pipe Hangers and Supports - Fabrication and Installation Practices.
- .5 National Research Council Canada (NRC)
  - .1 National Plumbing Code of Canada 2015(NPC).
- .6 Underwriter's Laboratories of Canada (ULC)

**1.2 ACTION AND INFORMATIONAL SUBMITTALS**

- .1 Provide submittals in accordance with Section 01 33 00- Submittal Procedures.
- .2 Product Data:
  - .1 Provide manufacturer's printed product literature and data sheets for hangers and supports and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Shop Drawings:
  - .1 Submit drawings stamped and signed by professional engineer registered or licensed in in Ontario, Canada.
  - .2 Submit shop drawings for:
    - .1 Bases, hangers and supports.
    - .2 Connections to equipment and structure.
    - .3 Structural assemblies.
- .4 Certificates:
  - .1 Submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.

- .5 Manufacturers' Instructions:
  - .1 Provide manufacturer's installation instructions.
    - .1 Departmental Representative will make available 1 copy of systems supplier's installation instructions.

### **1.3 CLOSEOUT SUBMITTALS**

- .1 Provide maintenance data for incorporation into manual specified in Section 01 78 00- Closeout Submittals.

### **1.4 DELIVERY, STORAGE AND HANDLING**

- .1 Deliver, store and handle materials in accordance with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements:
  - .1 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
- .3 Packaging Waste Management: remove for reuse and return of padding, packaging materials, crates, pallets, in accordance with Section 01 00 10 – General Instructions.

## **Part 2 Products**

### **2.1 SYSTEM DESCRIPTION**

- .1 Design Requirements:
  - .1 Construct pipe hanger and support to manufacturer's recommendations utilizing manufacturer's regular production components, parts and assemblies.
  - .2 Base maximum load ratings on allowable stresses prescribed by ASME B31.1 or MSS SP58.
  - .3 Ensure that supports, guides, anchors do not transmit excessive quantities of heat to building structure.
  - .4 Design hangers and supports to support systems under conditions of operation, allow free expansion and contraction, prevent excessive stresses from being introduced into pipework or connected equipment.
  - .5 Provide for vertical adjustments after erection and during commissioning. Amount of adjustment in accordance with MSS SP58.
- .2 Performance Requirements:
  - .1 Design supports, platforms, catwalks, hangers to withstand seismic events. Provide cross bracing for the deaerator and condensate tank support for seismic loading.

### **2.2 GENERAL**

- .1 Fabricate hangers, supports and sway braces in accordance with MSS SP58. ANSI B31.1 and

- .2 Use components for intended design purpose only. Do not use for rigging or erection purposes.

## 2.3 PIPE HANGERS

- .1 Finishes:
  - .1 Pipe hangers and supports: galvanized after manufacture.
  - .2 Use hot dipped galvanizing process.
  - .3 Ensure steel hangers in contact with copper piping are epoxy coated.
- .2 Upper attachment structural: suspension from lower flange of I-Beam:
  - .1 Cold piping NPS 2 maximum: malleable iron C-clamp with hardened steel cup point setscrew, locknut carbon steel retaining clip.
    - .1 Rod: 13 mm FM approved.
  - .2 Cold piping NPS 2 1/2 or greater, hot piping: malleable iron beam clamp, eye rod, jaws and extension with carbon steel retaining clip, tie rod, nuts and washers, UL listed FM approved.
- .3 Upper attachment structural: suspension from upper flange of I-Beam:
  - .1 Cold piping NPS 2 maximum: ductile iron top-of-beam C-clamp with hardened steel cup point setscrew, locknut and carbon steel retaining clip, FM approved UL listed.
  - .2 Cold piping NPS 2 1/2 or greater, hot piping: malleable iron top-of-beam jaw-clamp with hooked rod, spring washer, plain washer and nut UL listed FM approved.
- .4 Upper attachment to concrete:
  - .1 Ceiling: carbon steel welded eye rod, clevis plate, clevis pin and cotters with weldless forged steel eye nut. Ensure eye 6mm minimum greater than rod diameter.
  - .2 Concrete inserts: wedge shaped body with knockout protector plate UL listed FM approved to MSS SP69.
- .5 Hanger rods: threaded rod material to MSS SP58:
  - .1 Ensure that hanger rods are subject to tensile loading only.
  - .2 Provide linkages where lateral or axial movement of pipework is anticipated.
  - .3 Do not use 22mm or 28mm rod.
- .6 Pipe attachments: material to MSS SP58:
  - .1 Attachments for steel piping: carbon steel galvanized.
  - .2 Attachments for copper piping: copper plated black steel.
  - .3 Use insulation shields for hot pipework.
  - .4 Oversize pipe hangers and supports.
- .7 Adjustable clevis: material to MSS SP69 UL listed FM approved, clevis bolt with nipple spacer and vertical adjustment nuts above and below clevis.

- .1 Ensure "U" has hole in bottom for rivetting to insulation shields.
- .8 Yoke style pipe roll: carbon steel yoke, rod and nuts with cast iron roll, to MSS SP69.
- .9 U-bolts: carbon steel to MSS SP69 with 2 nuts at each end to ASTM A563.
  - .1 Finishes for steel pipework: galvanized.
  - .2 Finishes for copper, glass, brass or aluminum pipework: black epoxy coated galvanized, with formed portion plastic coated.
- .10 Pipe rollers: cast iron roll and roll stand with carbon steel rod to MSS SP69.

## **2.4 RISER CLAMPS**

- .1 Steel or cast iron pipe: galvanized carbon steel to MSS SP58, type 42, FM approved UL listed.
- .2 Copper pipe: carbon steel copper plated to MSS SP58, type 42.
- .3 Bolts: to ASTM A307.
- .4 Nuts: to ASTM A563.

## **2.5 INSULATION PROTECTION SHIELDS**

- .1 Insulated cold piping:
  - .1 64 kg/m<sup>3</sup> density insulation plus insulation protection shield to: MSS SP69, galvanized sheet carbon steel. Length designed for maximum 3 m span.
- .2 Insulated hot piping:
  - .1 Curved plate 300 mm long, with edges turned up, welded-in centre plate for pipe sizes NPS 12 and over, carbon steel to comply with MSS SP69.

## **2.6 CONSTANT SUPPORT SPRING HANGERS**

- .1 Springs: alloy steel to ASTM A125, shot peened, magnetic particle inspected, with +/-5% spring rate tolerance, tested for free height, spring rate, loaded height and provided with Certified Mill Test Report (CMTR).
- .2 Load adjustability: 10% minimum adjustability each side of calibrated load. Adjustment without special tools. Adjustments not to affect travel capabilities.
- .3 Provide upper and lower factory set travel stops.
- .4 Provide load adjustment scale for field adjustments.
- .5 Total travel to be actual travel + 20%. Difference between total travel and actual travel 25 mm minimum.
- .6 Individually calibrated scales on each side of support calibrated prior to shipment, complete with calibration record.

## **2.7 VARIABLE SUPPORT SPRING HANGERS**

- .1 Vertical movement: 13 mm minimum, 50 mm maximum, use single spring pre-compressed variable spring hangers.

- .2 Vertical movement greater than 50 mm: use double spring pre-compressed variable spring hanger with 2springs in series in single casing.
- .3 Variable spring hanger complete with factory calibrated travel stops. Provide certificate of calibration for each hanger.
- .4 Steel alloy springs: to ASTM A125, shot peened, magnetic particle inspected, with +/-5 % spring rate tolerance, tested for free height, spring rate, loaded height and provided with CMTR.

## **2.8 EQUIPMENT ANCHOR BOLTS AND TEMPLATES**

- .1 Provide templates to ensure accurate location of anchor bolts.

## **2.9 HOUSE-KEEPING PADS**

- .1 Provide 100 mm high concrete housekeeping pads for base-mounted equipment; size pads 50mm larger than equipment; chamfer pad edges.

## **Part 3 Execution**

### **3.1 MANUFACTURER'S INSTRUCTIONS**

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

### **3.2 INSTALLATION**

- .1 Install in accordance with:
  - .1 Manufacturer's instructions and recommendations.
- .2 Vibration Control Devices:
  - .1 Install on piping systems at pumps, boilers, chillers, cooling towers, and as indicated.
- .3 Clamps on riser piping:
  - .1 Support independent of connected horizontal pipework using riser clamps and riser clamp lugs welded to riser.
  - .2 Bolt-tightening torques to industry standards.
  - .3 Steel pipes: install below coupling or shear lugs welded to pipe.
  - .4 Cast iron pipes: install below joint.
- .4 Clevis plates:
  - .1 Attach to concrete with 4minimum concrete inserts, one at each corner.
- .5 Provide supplementary structural steelwork where structural bearings do not exist or where concrete inserts are not in correct locations.
- .6 Use approved constant support type hangers where:

- .1 Vertical movement of pipework is 13 mm or more,
- .2 Transfer of load to adjacent hangers or connected equipment is not permitted.
- .7 Use variable support spring hangers where:
  - .1 Transfer of load to adjacent piping or to connected equipment is not critical.
  - .2 Variation in supporting effect does not exceed 25 % of total load.

### 3.3 HANGER SPACING

- .1 Plumbing piping: to National Plumbing Code of Canada (NPC) and authority having jurisdiction.
- .2 Fire protection: to applicable fire code.
- .3 Gas and fuel oil piping: up to NPS 1/2: every 1.8 m.
- .4 Copper piping: up to NPS 1/2: every 1.5 m.
- .5 Flexible joint roll groove pipe: in accordance with table below for steel, but not less than one hanger at joints. Table listings for straight runs without concentrated loads and where full linear movement is not required.
- .6 Within 300mm of each elbow.

Maximum Pipe Size : NPS	Maximum Spacing Steel	Maximum Spacing Copper
up to 1-1/4	2.4 m	1.8 m
1-1/2	3.0 m	2.4 m
2	3.0 m	2.4 m
2-1/2	3.7 m	3.0 m
3	3.7 m	3.0 m
3-1/2	3.7 m	3.3 m
4	3.7 m	3.6 m
5	4.3 m	
6	4.3 m	
8	4.3 m	
10	4.9 m	
12	4.9 m	

- .7 Pipework greater than NPS 12: to MSS SP69.

### 3.4 HANGER INSTALLATION

- .1 Install hanger so that rod is vertical under operating conditions.
- .2 Adjust hangers to equalize load.
- .3 Support from structural members. Where structural bearing does not exist or inserts are not in suitable locations, provide supplementary structural steel members.

### 3.5 HORIZONTAL MOVEMENT

- .1 Angularity of rod hanger resulting from horizontal movement of pipework from cold to hot position not to exceed 4 degrees from vertical.

- .2 Where horizontal pipe movement is less than 13 mm, offset pipe hanger and support so that rod hanger is vertical in the hot position.

### **3.6 FINAL ADJUSTMENT**

- .1 Adjust hangers and supports:
  - .1 Ensure that rod is vertical under operating conditions.
  - .2 Equalize loads.
- .2 Adjustable clevis:
  - .1 Tighten hanger load nut securely to ensure proper hanger performance.
  - .2 Tighten upper nut after adjustment.
- .3 C-clamps:
  - .1 Follow manufacturer's recommended written instructions and torque values when tightening C-clamps to bottom flange of beam.
- .4 Beam clamps:
  - .1 Hammer jaw firmly against underside of beam.

### **3.7 FIELD QUALITY CONTROL**

- .1 Site Tests: conduct following tests in accordance with Section 01 45 00- Quality Control and submit report as described in PART 1 - ACTION AND INFORMATIONAL SUBMITTALS.
- .2 Manufacturer's Field Services:
  - .1 Obtain written report from manufacturer verifying compliance of Work, in handling, installing, applying, protecting and cleaning of product and submit Manufacturer's Field Reports as described in PART 1 - ACTION AND INFORMATIONAL SUBMITTALS.
  - .2 Provide manufacturer's field services consisting of product use recommendations and periodic site visits for inspection of product installation in accordance with manufacturer's instructions.
  - .3 Schedule site visits, to review Work, as directed in PART 1 - QUALITY ASSURANCE.

### **3.8 CLEANING**

- .1 Clean in accordance with Section 01 74 11- Cleaning.
  - .1 Remove surplus materials, excess materials, rubbish, tools and equipment.
- .2 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 00 10 – General Instructions.

**END OF SECTION**