



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving - PWGSC / Réception des soumissions -
TPSGC

11 Laurier St. / 11, rue Laurier
Place du Portage, Phase III
Core 0B2 / Noyau 0B2
Gatineau, Québec K1A 0S5
Bid Fax: (819) 997-9776

Revision to a Request for a Standing Offer

Révision à une demande d'offre à commandes

National Master Standing Offer (NMSO)

Offre à commandes principale et nationale (OCPN)

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Offer remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'offre demeurent les mêmes.

Comments - Commentaires

THIS DOCUMENT CONTAINS A SECURITY REQUIREMENT for requirements at Appendix E" only.

A copy of the award summary for E60HL-190020/A is available upon request to:
Ann.lacelle@pwgsc-tpsgc.gc.ca

Vendor/Firm Name and Address

Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Fuel & Construction Products Division
L'Esplanade Laurier,
140 O'Connor Street,
East Tower, 4th floor,
Ottawa
Ontario
K1A 0S5

Title - Sujet DIESEL, GASOLINE & HEATING FUEL OIL	
Solicitation No. - N° de l'invitation E60HL-210020/A	Date 2021-07-06
Client Reference No. - N° de référence du client E60HL-210020	Amendment No. - N° modif. 002
File No. - N° de dossier hl636.E60HL-210020	CCC No./N° CCC - FMS No./N° VME
GETS Reference No. - N° de référence de SEAG PW-\$\$HL-636-80063	
Date of Original Request for Standing Offer 2021-05-20	
Date de la demande de l'offre à commandes originale	
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Eastern Daylight Saving Time EDT on - le 2021-07-12 Heure Avancée de l'Est HAE	
Address Enquiries to: - Adresser toutes questions à: Lacelle, Ann	Buyer Id - Id de l'acheteur hl636
Telephone No. - N° de téléphone (613) 296-3977 ()	FAX No. - N° de FAX () -
Delivery Required - Livraison exigée	
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	
Security - Sécurité This revision does not change the security requirements of the Offer. Cette révision ne change pas les besoins en matière de sécurité de la présente offre.	

Instructions: See Herein

Instructions: Voir aux présentes

Acknowledgement copy required	Yes - Oui	No - Non
Accusé de réception requis	<input type="checkbox"/>	<input type="checkbox"/>
The Offeror hereby acknowledges this revision to its Offer. Le proposant constate, par la présente, cette révision à son offre.		
Signature	Date	
Name and title of person authorized to sign on behalf of offeror. (type or print) Nom et titre de la personne autorisée à signer au nom du proposant. (taper ou écrire en caractères d'imprimerie)		
For the Minister - Pour le Ministre		

Amendment number 002 is raised to:

- add clauses; and
- respond to questions;
- remove a special instruction from 3 locations in Appendix A.

2) **AT: PART 4 – EVALUATION PROCEDURES AND BASIS OF SELECTION,
4.2 Basis of Selection**

INSERT:

4.2.1 In the event of identical lowest priced responsive offers for a consolidated requirement, preference will be given to the Offeror who offers the lowest responsive average unit price. The calculation of an Offeror's lowest responsive average unit price will be determined by calculating the sum of the estimated quantities where the Offeror submits the lowest responsive price per consolidated requirement(s), and dividing it by the sum of the extended unit price values for those same consolidated requirement(s). The calculation shall include the identical priced consolidated requirement.

3) **AT: PART 7 – STANDING OFFER AND RESULTING CONTRACT CLAUSES
B. RESULTING CONTRACT CLAUSES
7.3 Term of Contract
7.3.1 Delivery Date**

INSERT:

The supplier must put in place adequate measures to ensure that fuel deliveries will occur, within the prescribed lead time, even in case of an emergency (e.g.: power outage, tornado, flood, etc.).

Q.1.) "Just glanced through the tender and saw one requirement (NT061) which I'm wondering about the tank size given the volume and the required number of deliveries (1,000 litre storage with 2,000,000 litres estimated quantity). It is on page 532.

Another one which is high as well when reviewing the number of deliveries is on page 533 with storage of 2,500L and quantity of 250,000L."

A.1.) (RFSO – Appendix "F" NT101 32/TW, and NT061 27/PU) The information provided with reference to estimated quantities is currently correct as listed, and is an estimate only.

In addition, and with reference to "page 533" (RFSO – Appendix "F" NT061 27/PU), please note this is a pick-up requirement.

Q.2) "On page 390 of 460, 7CFSD Edmonton. It states that the tank is 25KL, but the Estimated Quantity is only 2500L. Can we please get some clarification on this one."

A.2.) (RFSO – Appendix "A" AB101 39/TW) The information provided with reference to estimated quantities is currently correct as listed, and is an estimate only.

Q.3.) “On page 392 of 460, DND Lancaster Park. There’s 2 million litres of Estimated Quantity, but no tank size. Under Instructions, it says, « Bottom loading distance from gate 25KM , what does this mean? (Could it be 25 meters?)”

A.3.) (RFSO – Appendix “A” AB101 3/PU) The information provided with reference to estimated quantities is currently correct as listed, and is an estimate only. Please note that this is a pick-up requirement.

Q.4.) “On page 393 of 460, DND Lancaster Park. There’s a 100KL of Estimated Quantity of gas, but no tank size. It also references the distance from gate 25KM (?), in the Instructions.”

A.4.) (RFSO – Appendix “A” AB101 14/PU) The information provided with reference to estimated quantities is currently correct as listed, and is an estimate only. Please note that this is a pick-up requirement.

Q.5.) “On page 394 of 460, DND Lancaster Park. They reference 200KL of P50, but no tank size.”

A.5.) (RFSO – Appendix “A” AB101 27/PU) The information provided with reference to estimated quantities is currently correct as listed, and is an estimate only. Please note that this is a pick-up requirement.

Q.6) “Can you confirm if a pump is required for all of these or are they gravity drop?”

Zone	Location	Product	Tank Size	[Estimated] Annual Volume	R.6.
NB121	DND, CFB Gagetown Bulk Fuel Facility L-60 Oromocto, NB	ULS Diesel	2 X 75,834	4,500,000	No additional information is available.
NB121	DND, New Central Heating Plant Bldg C-9 Oromocto, NB	Furnace Oil	520,842	500,000	No additional information is available.
NS331	DND, CFB Greenwood Bldg 216 (new CHP) Greenwood Kings Co, NS	Furnace Oil	2 x 409,903	3,200,000	No additional information is available.
NS331	DND CFB Greenwood, various Bldgs. Greenwood Kings Co, NS	Furnace Oil	108,000	500,000	No additional information is available.

NS221	DND/FCEO HMC Dockyard D204 Halifax, NS	Furnace Oil	455,000	350,000	No additional information is available.
NS161	CSC - Springhill Institute 330 McGee St Springhill Cumberland Co, NS	Furnace Oil	2 X 60,000	1,000,000	Pump is required
NS161	CFB - Shearwater 85 Provider Ave - SH349 -	Furnace Oil	125,000	650,000	No additional information is available.

Q.7.) Are these annual volumes that appear in lots (QTY/ planned), or for two years?

A.7.) The estimated quantities found at Appendix "A", "E", and "F" reflect the period from September 1, 2021 to August 31, 2023.

Q.8) It has come to our attention that the volume in the NS331 zone below, may not be what is stated as it seems the location has switched to natural gas, in Bldg 216(new CHP)below in yellow. Perhaps they will have furnace as back up?

A.8) (RFSO – Appendix "A" NS331 8/TW – delivery to DND, CFB Greenwood, Bldg 216 (new CHP), Greenwood Kings Co, NS – 2 x 409,903, estimated quantity 6,400,000 L) The information provided with reference to estimated quantities is currently correct as listed, and is an estimate only.

Q.9) One of our Transports is not familiar with the following: "2.5" Guillontine drop tube is required." In Zone AB051 5/TW. Is there someone who can clarify?

A.9.) Parks Canada: "we no longer require that attachment as we are only have gravity drop fuel deliveries"

**4.) AT: Appendix A,
Consolidated requirements AB051 5/TW and AB051 39/TW**

DELETE: Instructions: "2.5" Guillotine drop tube is required".

All other terms and conditions of the Request for Standing Offer remain unchanged.