



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

**Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Public Works and Government Services Canada - Pacific
Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Comm Tower & Support Infrastructure Discovery Mountain Communication & Support Infrastructure	
Solicitation No. - N° de l'invitation F1705-210292/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client F1705-210292	Date 2021-07-15
GETS Reference No. - N° de référence de SEAG PW-\$PWY-045-9014	
File No. - N° de dossier PWY-1-44027 (045)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM Pacific Daylight Saving Time PDT on - le 2021-07-29 Heure Avancée du Pacifique HAP	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Mountford, Elsie	Buyer Id - Id de l'acheteur pwy045
Telephone No. - N° de téléphone (236) 464-3238 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO - Discovery Mountain - Campbell River, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
F1705-210292/A

Amd. No. - N° de la modif.
001

Buyer ID - Id de l'acheteur
PWY045

Client Ref. No. - N° de réf. du client
F1705-210292

File No. - N° du dossier

CCC No./N° CCC - FMS No./N° VME

This Amendment 001 is raised to:

- Extend the closing date of the solicitation
- List of Attendees for the Mandatory Bidders Conference on Wednesday, July 14, 2021.
- Issue Addendum 001

.....

Solicitation Amendment 001 is Raised to Extend the Solicitation Closing Date to 2021-07-29 at 2:00 PM Pacific Daylight Time (PDT).

Solicitation No. - N° de l'invitation
F1705-210292/A

Amd. No. - N° de la modif.
001

Buyer ID - Id de l'acheteur
PWY045

Client Ref. No. - N° de réf. du client
F1705-210292

File No. - N° du dossier

CCC No./N° CCC - FMS No./N° VME

List of Attendees for the Bidders Conference

Industra

J.W. Project Management Ltd.

Ketza Pacific Construction (1993) Ltd.

Ketza Pacific Contracting Ltd.

Luxton Construction

Robson Design Build Ltd.

Seafirst Construction Corp.

Tetra Tech Canada Inc.

Tridon Communications

WesTower Communications

Solicitation No. - N° de l'invitation
F1705-210292/A

Amd. No. - N° de la modif.
001

Buyer ID - Id de l'acheteur
PWY045

Client Ref. No. - N° de réf. du client
F1705-210292

File No. - N° du dossier

CCC No./N° CCC - FMS No./N° VME

See Addendum 001 below.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.

PROJECT TITLE: Discovery Mountain Communication Tower and Supporting Infrastructure

CONTRACT: F1705-210292

DATE: July 15, 2021

The following are effective immediately and form part of the contract documents.

QUESTIONS

Question 1:

Our Tower Erection team would be compliant with the “Helicopter Access” and “placement of reinforced concrete” on similar projects. Would that allow for meeting of the requirement in the General Contractor section? Can we refer by note to review in the “Tower Erection (Sub) Contractor in this section?

Answer 1:

As per Appendix 5 – Qualifications Form 1) General Contractor, the General Contractor must have experience in completing projects of a similar nature. A sub-contractor cannot be used to meet this requirement for the General Contractor.

Question 2:

We have been the General Contractor on projects in excess of your minimum but they have not been identical to this project. Our “Tower Erector (Sub) Contractor has been in this industry and continues to perform in this work. If successful in the tender, then we can provide information.

Answer 2:

Refer to Answer 1.

DRAWINGS

The contract drawings have been revised and re-issued under Revision Number 01.

SPECIFICATIONS

Section 01 35 43 – Environmental Procedures

PART 1 GENERAL

1.1 RELATED SECTIONS

Add

- .7 Environmental Protection Plan – Discovery Mountain by Stantec Inc., attached in Appendix E.

Section 13 36 13.13 – Steel Towers

PART 1 GENERAL

1.8 DESIGN REQUIREMENTS

Replace

.7 The maximum face width of the tower is 6.0m

with

.7 The maximum face width of the tower is 4.0m

APPENDICES

UPDATE

APPENDIX	SECTION TITLE	NO. OF PAGES
Appendix B	Geotechnical Report (<i>Updated May 31, 2021</i>)	10

ADD

APPENDIX	SECTION TITLE	NO. OF PAGES
Appendix E	Environmental Protection Plan – Discovery Mountain	28

END OF ADDENDUM NO. 001