



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

Bid Receiving - PWGSC / Réception des soumissions -  
TPSGC

11 Laurier St./11 rue Laurier

Place du Portage, Phase III

Core 0B2 / Noyau 0B2

Gatineau, Québec K1A 0S5

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**

Raison sociale et adresse du  
fournisseur/de l'entrepreneur

**Issuing Office - Bureau de distribution**

Construction Services Division/Division des services de  
construction

140 O'Connor Street

140, rue O'Connor

Ontario

Ottawa

K1A 0S5

<b>Title - Sujet</b> Deaerator and Condensate Tank Replacement	
<b>Solicitation No. - N° de l'invitation</b> EP916-212828/A	<b>Amendment No. - N° modif.</b> 006
<b>Client Reference No. - N° de référence du client</b> 20212828	<b>Date</b> 2021-07-26
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$\$\$FG-378-80149	
<b>File No. - N° de dossier</b> fg378.EP916-212828	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> Eastern Daylight Saving Time EDT <b>on - le 2021-08-05</b> Heure Avancée de l'Est HAE	
<b>F.O.B. - F.A.B.</b>	
<b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Larocque, Cody	<b>Buyer Id - Id de l'acheteur</b> fg378
<b>Telephone No. - N° de téléphone</b> (343) 552-8199 ( )	<b>FAX No. - N° de FAX</b> ( ) -
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

**The following changes to the tender documents are effective immediately. This amendment will form part of the contract documents.**

Amendment 006 is issued for the following:

1. Due to technical problems, Addendum 1 was not included. Find herewith these documents.
- 

**ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME**

Solicitation No. - N° de l'invitation  
EP916-212828/A

Amd. No. - N° de la modif.  
006

Buyer ID - Id de l'acheteur  
FG378

Client Ref. No. - N° de réf. du client  
R.065220.772

File No. - N° du dossier  
fg378.EP916-212828

CCC No./N° CCC - FMS No./N° VME

---

## **ADDENDUM 01**

**Date** July 20, 2021  
**Addendum No.** 1  
**Project No.** R.065220.772

**The following changes in the bid documents are effective immediately.**

**This addendum will form part of the construction documents.**

**DRAWINGS:**

- 1 Mechanical**
  - a. M101 - Mechanical Site Plan, Schematics and Drawing Legend
  - b. M102 - Auxiliary Tie-In Connections for Mobile Steam Plant
  
- 2 Electrical**
  - a. E501 - Auxiliary Tie-In Connections for Mobile Steam Plant Power

**DESCRIPTION**

- 1.1 Contractor to provide one (1) mobile steam boiler of capacity 500 BHP for the duration of the heating season, include for full rental costs and operation costs for the mobile steam plant including all hook up, and disconnecting of mobile steam plant to service this project. The duration for the mobile steam boiler rental will be from October 15<sup>th</sup> to April 15<sup>th</sup> (6 months).
- 1.2 Contractor shall coordinate with rental supplier to provide a stable, well drained, compacted, granular pad suitable to support the equipment with allowable movement tolerance to the equipment for the duration of the rental period to install the mobile steam plant as per rental supplier's guidelines. The proposed location of the mobile steam plant is shown in drawing M101.
- 1.3 Contractor to provide auxiliary tie in points to the main Steam and Condensate headers, for the connection of a mobile steam plant. Refer drawing M102 included along with this addendum.
- 1.4 Contractor to provide all other auxiliary tie in points to the softeners, boiler blowdown tank, natural gas connection, condensate overflow line for the connection of a mobile steam plant. Refer drawing M102 included along with this addendum.

- 1.5 Contractor shall provide guard rails and other suitable means to secure and safeguard temporary piping between temporary boiler and the building.
- 1.6 Contractor to include for temporary power connection from building MCC, including adequate disconnecting means, to a mobile steam plant.
- 1.7 Contractor shall retain the service of existing controls contractor to provide a common alarm signal from PID controller of the mobile steam plant to the BAS for receiving trouble alarm in the BAS.
- 1.8 The rental mobile steam boiler shall meet the requirements of TSSA as “Unattended” in the province of Ontario.
- 1.9 The rental company shall provide training for the operation of the unit prior to formal “hand-off”.
- 1.10 Mobile steam boiler, piping and feedwater system must be kept above the freezing temperature at all times, during and after operation and also during transportation and storage.
- 1.11 All new connections to the mobile steam plant including the mobile steam plant are to be installed in accordance with all applicable codes and regulations of the jurisdictional authority.
- 1.12 Question: Can you provide the nameplate and/or specs for panel MCC-01 (make, model, kA rating)?  
Response:  
Manufacturer; Klockner – Moeller  
ID#: Type: NA 600 MCC #1  
Voltage: 600 v  
Phase: 3Ø  
Frequency: 60 Hz  
Control Voltage: 120v  
Order NO : 68/12/0339

\*End of Addendum\*